

HMS, Inc.
HAZARD MANAGEMENT SERVICES, INC.

January 13, 1994

Mr. Rob Peters
Chico Unified School District
1163 E. Seventh Street
Chico, CA 95928

Dear Mr. Peters:

Please find enclosed, additional documentation from AC Industrial regarding the Pleasant Valley High school project. Insert these pages into the appropriate places in your district book and copy for the school book. It is my understanding this will probably be all the paperwork we will receive from AC Industrial on this job.

Should you have any questions, please feel free to contact me at (916) 723-4350.

Sincerely,



Terri Busch
Executive Secretary

Enclosures

X. DESCRIPTION OF PLANNED DEMOLITION OR RENOVATION WORK, AND METHOD(S)

Removal of old Boiler

XI. DESCRIPTION OF WORK PRACTICES AND ENGINEERING CONTROLS TO BE USED TO PREVENT EMISSIONS OF ASBESTOS AT THE DEMOLITION AND RENOVATION SITE:

Gross abatement of all ACM prior to removal of Boiler

XII. WASTE TRANSPORTER #1

NAME: *A/C Industrial Services Corp*

ADDRESS: *1111 Macauley St.*

CITY: *Chicago*

STATE: *CA*

ZIP: *95926*

CONTACT PERSON: *James M. Rich*

TELEPHONE: *(916) 343-5488*

WASTE TRANSPORTER #2

NAME:

ADDRESS:

CITY:

STATE:

ZIP:

CONTACT PERSON:

TELEPHONE:

XIII. WASTE DISPOSAL SITE

NAME: *Anderson Solid Waste Inc.*

LOCATION: *18703 Cambridge Rd.*

CITY: *Anderson*

STATE: *CA*

ZIP: *96007*

TELEPHONE: *(916) 347-5236*

XIV. IF DEMOLITION ORDERED BY A GOVERNMENT AGENCY, PLEASE IDENTIFY THE AGENCY BELOW:

NAME:

TITLE:

AUTHORITY:

DATE OF ORDER (MM/DD/YY):

DATE ORDERED TO BEGIN (MM/DD/YY):

XV. FOR EMERGENCY RENOVATIONS

DATE AND HOUR OF EMERGENCY (MM/DD/YY):

DESCRIPTION OF THE SUDDEN, UNEXPECTED EVENT:

EXPLANATION OF HOW THE EVENT CAUSED UNSAFE CONDITIONS OR WOULD CAUSE EQUIPMENT DAMAGE OR AN UNREASONABLE FINANCIAL BURDEN:

XVI. DESCRIPTION OF PROCEDURES TO BE FOLLOWED IN THE EVENT THAT UNEXPECTED ASBESTOS IS FOUND OR PREVIOUSLY NONFRIABLE ASBESTOS MATERIAL BECOMES CRUMBLED, PULVERIZED, OR REDUCED TO POWDER. *Gross Net Removal*

XVII. I CERTIFY THAT AN INDIVIDUAL TRAINED IN THE PROVISIONS OF THIS REGULATION (40 CFR PART 61, SUBPART M) WILL BE ON-SITE DURING THE DEMOLITION OR RENOVATION AND EVIDENCE THAT THE REQUIRED TRAINING HAS BEEN ACCOMPLISHED BY THIS PERSON WILL BE AVAILABLE FOR INSPECTION DURING NORMAL BUSINESS HOURS (REQUIRED 1 YEAR AFTER PROMULGATION).

James M. Rich
(SIGNATURE OF OWNER/OPERATOR)

7-7-94
(DATE)

XVIII. I CERTIFY THAT THE ABOVE INFORMATION IS CORRECT.

James M. Rich
(SIGNATURE OF OWNER/OPERATOR)

7-7-94
(DATE)

OPERATOR PROJECT #	POSTMARK	DATE RECEIVED	NOTIFICATION #		
I. TYPE OF NOTIFICATION (O-ORIGINAL R-REVISED C-CANCELLED):				WPR Notice?	
II. FACILITY INFORMATION (IDENTIFY OWNER, REMOVAL CONTRACTOR, AND OTHER OPERATOR)					
OWNER NAME: <u>Chico Unified School Dist. P.V. High School</u>					
ADDRESS: <u>1475 East Ave</u>					
CITY: <u>Chico</u>	STATE: <u>CA</u>	ZIP: <u>95926</u>			
CONTACT: <u>Ray Jones</u>		TEL: <u>891-3</u>			
REMOVAL CONTRACTOR: <u>A/C Industrial Services Corp</u>					
ADDRESS: <u>1111 Marauder St.</u>					
CITY: <u>Chico</u>	STATE: <u>CA</u>	ZIP: <u>95926</u>			
CONTACT: <u>James M. Rich</u>		TEL: <u>343-5488</u>			
OTHER OPERATOR:					
ADDRESS:					
CITY:	STATE:	ZIP:			
CONTACT:		TEL:			
III. TYPE OF OPERATION (D-DEMO O-ORDERED DEMO R-RENOVATION E-EMER.RENOVATION): <u>R</u>					
IV. IS ASBESTOS PRESENT? (YES/NO) <u>Yes</u>					
V. FACILITY DESCRIPTION (INCLUDE BUILDING NAME, NUMBER AND FLOOR OR ROOM NUMBER)					
BLDG NAME: <u>Building Cochran Rooms (Room # 205) Unit F</u>					
ADDRESS: <u>1475 East Ave</u>					
CITY: <u>Chico</u>	STATE: <u>CA</u>	COUNTY: <u>95926</u>			
SITE LOCATION: <u>Boiler Room</u>					
BUILDING SIZE: <u>5,000 sq ft.</u>	NUM OF FLOORS: <u>1</u>	AGE IN YEARS: <u>28</u>			
PRESENT USE: <u>Boiler Room</u>		PRIOR USE: <u>Boiler Room</u>			
VI. PROCEDURE, INCLUDING ANALYTICAL METHOD, IF APPROPRIATE, USED TO DETECT THE PRESENCE OF ASBESTOS MATERIAL: <u>Personal Air monitoring per AHERA.</u>					
VII. APPROXIMATE AMOUNT OF ASBESTOS, INCLUDING:		NONFRIABLE ASBESTOS MATERIAL NOT TO BE REMOVED		INDICATE UNIT OF MEASUREMENT BELOW	
1. REGULATED ACM TO BE REMOVED		RACH TO BE REMOVED	CAT I	CAT II	UNIT
2. CATEGORY I ACM NOT REMOVED					
3. CATEGORY II ACM NOT REMOVED					
PIPES	<u>60 e/bows</u>				Ln Ft: <u>60</u> Ln m:
SURFACE AREA	<u>540 sq ft</u>				Sq Ft: <u>540</u> Sq m:
VOL RACH OFF FACILITY COMPONENT					Cu Ft: Cu m:
VIII. SCHEDULED DATES ASBESTOS REMOVAL (MM/DD/YY) START: <u>7-25-94</u> COMPLETE: <u>7-29-94</u>					
IX. SCHEDULED DATES DEMO/RENOVATION (MM/DD/YY) START: COMPLETE:					

7-27-94

8:10 AM Stopped by PVHS Border Room area. I spoke with Mark Oslund of AC Industrial who was supervising the abatement project. He told me Steve Easter would copy the "certs" for Robert Aguilar & Lawrence Rodriguez for us today.

He said the containment was in place and the crew was placing the decon unit as we spoke. He confirmed the abatement ~~project~~^{would be} finished today. He told me he couldn't get final air clearance from Penn Environmental Friday AM. Results will be available to AC on Sat. AM - Mark

7-26-93 R. Jones

1:00 PM Called A.C. - Told Mark Osland at PVH5

1:10 PM Arrived PVH5 Boiler
Area (outside)

Spoke with Mark Osland who
was working with Robert
Aguilar & Lawrence Rodriguez
of Cal Coast (Sub Contractor)

I was told by Mark that
they would finish building the
containment, ~~for~~ decon unit
& probably glove bag some elbows
today.

He plans to have the abatement
finished ~~there~~ Wednesday 7-27-
94 with air sampling on 7-28-94
JEM.

Would like Keys to Gate
& Boiler Room to allow
for tear down on Saturday.

Crew for today is:

Mark Osland / AC Industrial
Jeremy Sowul / AC Industrial
Robert Aguilar / Cal Coast
Lawrence Rodriguez / Cal Coast

8:20 Departed PVHS

Robin

Keys for Gate & Boiler

Room at PVHS are
needed to allow completion
of project on Saturday
by AC

RJ

A/C INDUSTRIAL SERVICES CORP.
Site Safety Plan
Chico Unified School District
Pleasant Valley High School

A.SITE DESCRIPTION

Date: 07-25-94 to 07-29-94

Location:Boiler Room

Hazards: Asbestos

Area Affected: Elbows and tank

Surrounding Population: City Community, Residential

Topography; Level, concrete.

Weather Conditions;Anticipated to be hot, dry with
temperatures in the mid 90's.

Additional Information;

B. ENTRY OBJECTIVES - The objective of the initial entry is to fully contain the area that has the tank and elbows to be removed. Removal will be done by gross wet removal methods.

C. ONSITE ORGANIZATION AND COORDINATION - The following personnel are designated to carry out the stated job function on site:

PROJECT TEAM LEADER:	Steve Easter
SCIENTIFIC ADVISOR:	NONE
SITE SAFETY OFFICER:	James M. Rich
PUBLIC INFORMATION OFFICER:	Rob Peters
SECURITY OFFICER:	NONE
RECORDKEEPER:	James M. Rich
FINANCIAL OFFICER:	Nick Buck
FIELD TEAM LEADER:	Steve Easter
FIELD TEAM MEMBERS:	James M. Rich Mark Osland 726 Jeremy Sowul

7-26
(Robert Aguilan)
Lawrence Rodriguez
Kelco/Cal Coast

FEDERAL AGENCY REPS (i.e., EPA, NIOSH)

NONE

STATE AGENCY REPS

NONE

LOCAL AGENCY REPS;

NONE

CONTRACTOR(S);

A/C Industrial Services Corp.

All personnel arriving or departing the site should log in and out with the recordkeeper.
All activities on site must be cleared through the project team leader.

D. ONSITE CONTROL

Steve Easter of A/C Industrial Services Corp. has been designated to coordinate access control and security on the job site. A safe perimeter has been established at a distance of 30' around the work site and is designated by Warning Signs.

No unauthorized person should be within the work area defined by the safe perimeter boundary. The onsite command post and staging area have been established at;

A/C Command E.R. vehicle (505)

Control boundaries have been established, and the Exclusion zone (the contaminated area), hotline, Contamination Reduction Zone, and Support Zone(clean area) have been identified and designated.

Boundary zones appropriate to degree of hazard. Use traffic cones.

These boundaries are identified by: (marking of zones, i.e., yellow boundary tape; traffic cones, etc.);

Asbestos Warning Signs

E. HAZARD EVALUATION

The following substance(s) are known or suspected to be on site. The primary hazards of each are identified.

Substances (Chemical Name)	Concentrations (If Known)	Primary Hazards (e.g., toxic)
Chrysotile Asbestos	5-10%	Raspatory

The following additional hazards are expected on site:

Falling hazards

Hazardous substance information form(s) for the involved substances have been completed and attached.

OHM/TADS
OSHA
MSDS

F. PERSONAL PROTECTIVE EQUIPMENT

Based on evaluation of potential hazards, the following levels of personal protection have been designated for the applicable work areas or tasks:

Location	Job Function	Level of Protection
Exclusion Zone	removal	A B <input checked="" type="radio"/> D Other
		A B C D Other
		A B C D Other
		A B C D Other
Contamination reduction Zone	Decon	A B <input checked="" type="radio"/> D Other
		A B C D Other
		A B C D Other
		A B C D Other

Specific protective equipment for each level of protection is as follows:

Level A Fully-encapsulating suit
SCBA,

Level C Splash gear(type)
disposable coveralls
Full-face Resp.

Level B Splash gear(type), SCBA

Level D
(Standby) Half-face Resp.
Overalls, Rubber boots.
Gloves, goggles, splash
gear, hardhats.

The following protective clothing materials are required for the involved substances.

Substance
(Chemical Name)

Material
(Material Name,e.g. viton)

Asbestos

Overalls
gloves
boots
safety goggles
Hard Hats
Splash Gear
1/2 face respirator

If air-purifying respirators are authorized, HEPA is the appropriate cartridge for use with the involved substances and concentrations. A competent individual has determined that all criteria for using this type of respiratory protection have been approved.

NO CHANGES TO THE SPECIFIED LEVELS OF PROTECTION SHALL BE MADE WITHOUT THE APPROVAL OF THE SITE SAFETY OFFICER AND THE PROJECT TEAM LEADER.

G. ONSITE WORK PLANS

Work party(s) consisting of 4 persons will perform the following task:

	(Function)
Project Team Leader	Prepare site safe
	Supervise operations
James M. Rich	Sampling
Steve Easter	

Work Party #1

Jeremy Sowul	Observer/labor
Steve Easter	Labor, Cleanup
Mark Osland	
James M. Rich	

Work Party #2

Rescue Team

Decontamination Team

All A/C Industrial Services Corp. personnel

The work party(s) were briefed on the contents of this plan at the site prior to start of work.

H. COMMUNICATION PROCEDURES

Channel 2 (FM) has been designated as the radio frequency for personnel in the Exclusion Zone. All other onsite communication will use channel 1. Personnel in the exclusion zone should remain in constant radio communication or within sight of the project team leader. Any failure of radio communication requires an evaluation of whether personnel should leave the exclusion zone.

Single horn blast is the emergency signal to indicate that all personnel should leave the exclusion zone. In addition, a loud hailer is available if required.

The following standard hand signals will be used in case of failure of radio communications:

Hand gripping throat.....	Out of air, can't breathe
Grip partners wrist or both hands around waist.	Leave area immediately
Hands on top of head.....	Need assistance
Thumbs up.....	OK, I'm all right
Thumbs down.....	No, Negative

Telephone communication to the command post should be established as soon as possible. The phone number is;

(916) 520-1823 cellular
520-4063 cellular

I. DECONTAMINATION PROCEDURES

Personnel and equipment leaving the exclusion zone shall be thoroughly decontaminated. The standard level decontamination protocol shall be used with the following decontamination stations:

(1) Remove soiled clothes	(2) Place in bag	(3)
(4) Soap & Water	(5)	(6)
(7)	(8)	(9)

Emergency decontamination will include the following stations:

Eye wash in first aid kit at command center.

The following decontamination equipment is required:

Towels.

Hand cream and water will be used as the decontamination solution. Soap is also acceptable.

J. SITE SAFETY AND HEALTH PLAN

1. James M. Rich is the designated site safety officer and is directly responsible to the project team leader for safety recommendations on site.
2. Emergency Medical Care

All A/C staff are CPR trained and are qualified First aid responders on site. The designated hospital is Enloe Hospital located at 5th and Esplanade, Chico, CA Phone 911. The Hospital will not be contacted briefed on the situation, the potential hazards, and the substances involved. A map of routes to this facility is available at the Command Center.

Local ambulance service is available from Chico at phone 911. Their response time is 5 to 10 minutes. Whenever possible, arrangements should be made for on site standby.

First aid equipment is available on site at the following locations: Command Center

Truck (505).

First aid kit

Emergency eye wash

Other:

Emergency medical information for substances present:

Substance	Exposure Symptoms	First Aid
Hydraulic fluid	Skin Burns	Eye Wash
Mineral spirits	Rash	Wash cuts If swallowed induce vomiting

Instructions:

Avoid fibers. Use HEPA

List of emergency phone numbers:

Agency/Facility	Phone #	Contact
Police-CHP	911	Dispatcher
Fire	911	Dispatcher
Hospital	911	
Emergency	911	
or A/C Industrial at	(916) 343-5488.	

Environmental Monitoring

The following environmental monitoring instruments shall be used on site at the specified intervals.

Combustible Gas Indicator	-periodically/hourly/daily/other
Oxygen Monitor	-periodically/hourly/daily/other
Colormetric tubes	-periodically/hourly/daily/other
Dosimeters	-periodically/hourly/daily/other
FID	-periodically/hourly/daily/other
PID	-periodically/hourly/daily/other
Geiger	-periodically/hourly/daily/other
Radon	-periodically/hourly/daily/other
HNU/OVA	-periodically/hourly/daily/other
other - Air Monitoring equipment	-periodically/hourly/ <u>daily</u> /other

4. Emergency Procedures

The following standard emergency procedures will be used by onsite personnel. The site safety officer shall be notified of any onsite emergencies and be responsible for ensuring that the appropriate procedures are followed.

Personal Injury in the Exclusion Zone:

Upon notification of an injury in the Exclusion Zone, the designated emergency signal ~~single horn blast~~ shall be sounded. All site personnel shall assemble at the decontamination line. The rescue team will enter the exclusion zone to remove the injured person to the hotline. The site safety officer and project team leader should evaluate the nature of the injury, and the affected person should be decontaminated to the extent possible prior to movement to the support zone. The project Team Leader shall initiate the appropriate first aid, and contact should be made for an ambulance through 911 and with the designated medical facility. No persons shall reenter the exclusion zone until the cause of the injury or the symptoms is determined.

Personnel Injury in the Support Zone:

Upon notification of an injury in the support zone, the project team leader and site safety officer will assess the nature of the injury. If the cause of the injury or loss of the injured person does not affect the performance of site personnel, operations may continue, with the Site Safety Officer initiating the appropriate first aid and necessary follow up as stated above. If the injury increases the risk to others, the designated emergency signal shall be sounded and all site personnel shall move to the decontamination line for further instructions. Activities on site will stop until the added risk is removed or minimized.

EXPOSURE MEASUREMENT RECORDKEEPING FORM

1. Date of exposure: 07-25-94 to 07-29-94
2. Job description: Asbestos Abatement of a tank and elbows.
3. Air sampling and analysis results are recorded on attached pages.
4. Type of protective devices worn:
Cloth coveralls, gloves, boots, hard hats, safety glasses and on standby half-face respirators with HEPA cartridges.
5. Employee roster on job:

PEL/TWA

NAME	SS#	EXPOSURE
1.		
2.		
3.		
4.		
5.		

All onsite personnel have read the above plan and are familiar with its provisions.

	NAME	Signature
Site Safety Officer:	_____	_____
Project Team Leader:	_____	_____
Other Personnel;	_____	_____
	_____	_____
	_____	_____
	_____	_____
	_____	_____
	_____	_____

IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802. WITHIN CALIFORNIA, CALL 1-800-852-7555

GENERATOR

TRANSPORTER

FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.	Manifest Document No.	2. Page 1 of 1	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address MINDO UNIFIED SCHOOL DIST 1475 EAST AVE MINDO, CA 95726		4. Generator's Phone (916) 434-1111		State Manifest Document Number 93029096	
5. Transporter 1 Company Name AK INDUSTRIAL SERVICES		6. US EPA ID Number MA1D19181316141463		State ID 401375	
7. Transporter 2 Company Name		8. US EPA ID Number		State ID 3435485	
9. Designated Facility Name and Site Address ANDERSON SOLID WASTE INC. 18703 CAMBRIDGE ROAD ANDERSON, CA 96007		10. US EPA ID Number MA1D19181318891512		State ID 401375	
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers No. Type		13. Total Quantity	
a. RC 222.2 1A 222 P203		0152 3A 600015		Y	
b.					
c.					
d.					
15. Special Handling Instructions and Additional Information WEAR PROTECTIVE CLOTHING WHILE HANDLING EMERGENCY CONTACT ROBERT KIMMALL (916) 343-5488		b. Handling Codes for Wastes Listed Above		c. Handling Codes for Wastes Listed Above	
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable federal, state and international laws. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.		Printed/Typed Name Dale Hays		Signature Dale Hays	
17. Transporter 1 Acknowledgement of Receipt of Materials		Printed/Typed Name JEREMY SOWUL		Signature Jeremy Sowul	
18. Transporter 2 Acknowledgement of Receipt of Materials		Printed/Typed Name		Signature	
19. Discrepancy Indication Space					
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.		Printed/Typed Name		Signature	

DO NOT WRITE BELOW THIS LINE.

Yellow: TSDF SENDS THIS COPY TO GENERATOR WITHIN 30 DAYS.
(Generators who submit hazardous waste for transport out-of-state, produce completed copy of this copy and send to DTSC within 30 days.)

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.	Manifest Document No.	2. Page 1 of 1	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address PVHS PACIFIC UNION SCHOOL DIST 1475 EAST AVE SACRAMENTO, CA 95811		A. State Manifest Document Number 93029096		B. State Generator's ID 147561629869	
4. Generator's Phone () 916 485-1111		C. State Transporter's ID 401235		D. Transporter's Phone 916 343-5485	
5. Transporter 1 Company Name AIR INDUSTRIAL SERVICES		6. US EPA ID Number 147561629869		E. State Transporter's ID 401235	
7. Transporter 2 Company Name		8. US EPA ID Number		F. Transporter's Phone	
9. Designated Facility Name and Site Address ANDERSON SOLID WASTE INC 15703 CAMBRIDGE ROAD ANDERSON, CA 91007		10. US EPA ID Number 147561629869		G. State Facility's ID 147561629869	
H. Facility's Phone 916 347-5236		11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers No. Type	
a. 1. 2212		055 BA 00005 Y		13. Total Quantity	
b.				14. Unit Wt/Vol	
c.				I. Waste Number State EPA/Other	
d.				State EPA/Other	
J. Additional Descriptions for Materials Listed Above ACID FROM BOILER TANK		K. Handling Codes for Wastes Listed Above a. b. c. d.			
15. Special Handling Instructions and Additional Information WEAR PROTECTIVE CLOTHING WHILE HANDLING EMERGENCY CONTACT ROBERT GINEALI (916) 292-4485					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable federal, state and international laws. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.					
Printed/Typed Name Dale Hines		Signature Dale Hines		Month Day Year 07 28 94	
17. Transporter 1 Acknowledgement of Receipt of Materials Printed/Typed Name JEREMY SOLIVE		Signature Jeremy Solive		Month Day Year	
18. Transporter 2 Acknowledgement of Receipt of Materials Printed/Typed Name		Signature		Month Day Year	
19. Discrepancy Indication Space					
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19. Printed/Typed Name Signature Month Day Year					

DO NOT WRITE BELOW THIS LINE.

10020

AC Indus

AC in

93029096 5

Anderson Solid Waste
18765 Cambridge Rd
Anderson Ca 96007

ID	29	GROSS	8940 (1)
VEHICLE	000000	TARE	7760
TIME	1:48 PM	NET	1180
DATE	08 03 94		

bill change

3250

Leaving FOR A/C
J-94-195
CHICO UNIFIED
SCHOOL DIST
P.V. HIGH

J-94-195

Notice and Certification

The waste identified on manifest number 73029096 and bearing the California Waste Code 151 is subject to land disposal restrictions contained in Article 40, Title 22, California Code of Regulations (CCR). The waste meets the definition of a treated hazardous waste pursuant to Health and Safety Code (H&SC) Section 25179.3(1)(2), which states that waste is considered treated if the waste does not contain any substances above the Soluble Thresholds Limit Concentration (STLC) values established in Article 11, Title 22, CCR; and the waste is not prohibited from land disposal as provided in H&SC Section 25179.6.

(Waste Analysis is attached for these wastes, where available.)

As required by Article 40, Title 22, CCR the following certification is made for these restricted wastes:

I certify under penalty of law that I personally have examined and am familiar with the waste through analysis and testing or through knowledge of the waste to support this certification that the waste complies with the treatment standards specified in CCR Title 22, Division 4, Chapter 30, Article 41. I believe that the information I submitted is true, accurate and complete. I am aware that there are significant penalties for submitting a false certification, including the possibility of fine and imprisonment.

Signature X

Title Fireman

Date 8-1-84

**NON-HAZARDOUS
WASTE MANIFEST**

1. Generator's US EPA ID No.

Manifest Doc. No.

2. Page 1

1 of

02-219

Generator's Name and Mailing Address

CHICO UNIFIED SCHOOL DISTRICT **SITE: PLEASANT VALLEY HIGH**
1163 EAST 4TH ST. CHICO, CA 95928 **1475 EAST AVE. CHICO**
925-299-3515

4. Generator's Phone (

5. Transporter 1 Company Name

6. CAL US EPA ID Number

A. Transporter's Phone

7. Transporter 2 Company Name

8. US EPA ID Number

B. Transporter's Phone

9. Designated Facility Name and Site Address

10. US EPA ID Number

C. Facility's Phone

U.S. JAIL
1410 HAY ROAD
VACAVILLE, CA 95687

CAD 982042475

707 451-3276

11. Waste Shipping Name and Description

12. Containers

No.

Type

13. Total Quantity

14. Unit Wt/Vol

a.

b.

c.

d.

02-10-01-25 Y

Additional Descriptions for Materials Listed Above

E. Handling Codes for Wastes Listed Above

JAMES CORPORATION, 1001 SHAWY CIRCLE, CONCORD, CA 94518 IN NR EMEA 925-969-9200
EPA REGION IX
RAAFMO, 939 ELLIS STREET, S.F., CA

15. Special Handling Instructions and Additional Information

16. **GENERATOR'S CERTIFICATION:** I certify the materials described above on this manifest are not subject to federal regulations for reporting proper disposal of Hazardous Waste.

Printed/Typed Name

Signature

Month Day Year

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

19. Discrepancy Indication Space

Facility Owner or Operator: Certification of receipt of waste materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

Signature

Month Day Year

*cc: Mary
 Kip
 Bob
 Sanchez (B)
 Mike*

COPY

GENERATOR

TRANSPORTER

FACILITY

Y

**NON-HAZARDOUS
WASTE MANIFEST**

1. Generator's US EPA ID No.

Manifest Doc. No.

2. Page 1

1 of

02-219

Generator's Name and Mailing Address

CHICO UNIFIED SCHOOL DISTRICT **SITE: PLEASANT VALLEY HIGH**
1163 EAST 4TH ST, CHICO, CA 95928 **1475 EAST AVE, CHICO**
925-299-3515

4. Generator's Phone (

5. Transporter 1 Company Name

6. CALIFORNIA EPA ID Number

A. Transporter's Phone

7. Transporter 2 Company Name

8. US EPA ID Number

B. Transporter's Phone

9. Designated Facility Name and Site Address

10. US EPA ID Number

C. Facility's Phone

B-S-1 LANDFILL
8920 HAY ROAD
VACAVILLE, CA 95687

C A D 9 8 2 0 4 2 4 7 5

707 451-3276

11. Waste Shipping Name and Description

NON-TRIPLE WASTE.

12. Containers

No.

Type

13. Total Quantity

14. Unit Wt/Vol

a.

b.

c.

d.

DC-1 KM 000-25 Y

Additional Descriptions for Materials Listed Above

E. Handling Codes for Wastes Listed Above

JARVIS CORPORATION, 1681 SHAW CIRCLE, CONCORD, CA 94518 24 HR EMER 925-969-9200
 EPA REGION IX
 RAAUMD, 939 ELLIS STREET, S.F., CA

15. Special Handling Instructions and Additional Information

16. **GENERATOR'S CERTIFICATION:** I certify the materials described above on this manifest are not subject to federal regulations for reporting proper disposal of Hazardous Waste.

Printed/Typed Name

Signature

Month Day Year

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

19. Discrepancy Indication Space

Facility Owner or Operator: Certification of receipt of waste materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

Signature

Month Day Year

cc: Mary
Kip
Rob
Bender (9)
Jeli
GENERATOR'S COPY

GENERATOR

TRANSPORTER

FACILITY

Y

SIX-MONTH SURVEILLANCE

Page 1 of 3

DISTRICT Chico Unified School DistrictDATE December 20, 1994SCHOOL Pleasant Valley HighINSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic area	7
A	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
B	PW Cnr	10-15	Attic area	7
B	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
C	PW Cnr	1-5	Attic area	7
C	Molded blk tabletops	Assumed	Room 20	1-4
C	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
D	PW Cnr	1-10	Attic area	7
D	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
E	PW Cnr	1-10	Attic over radio station	7
E	Plaster	1-5	Covered walk (outside)	2-4

CONDITION CODES

GENERAL CONDITION:

(1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION:

(4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

Page 2 of 3

DISTRICT Chico Unified School District DATE December 20, 1994SCHOOL Pleasant Valley Senior INSPECTOR Ron Jones *RJ*

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
F/G	Plaster	1-5	Covered walk (outdoors)	2-4
F	PW Str	40-60	Rm 55 B/R room	5-7 07/29/94
F	PW Str	40-60	Rm 54 storeroom	7
F	Tank wrap	35-45	B/R room	5-7 07/29/94
F	Debris & PW Cnr	15-20	Attic	2-4
F	Mud jnt	1-10	Room 54 storage	5-7 07/29/94
F	12 jnts	1-10	Small gym	5-7 07/29/94
G	Mud Jnt	1-10	Gym	5-7 07/29/94
H	Plaster	1-5	Covered Walk (outdoors)	1-4
I	Plaster	1-5	Covered Walk (outside)	2-4
I	Trans Wallboard	Assumed	Room 1 - Metal Shop	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

Page 1 of 3

DISTRICT Chico Unified School District DATE July 6, 1994SCHOOL Pleasant Valley High INSPECTOR Ron Jones *RJ*

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic area	7
A	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
B	PW Cnr	10-15	Attic area	7
B	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
C	PW Cnr	1-5	Attic area	7
C	Molded blk tabletops	Assumed	Room 20	1-4
C	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
D	PW Cnr	1-10	Attic area	7
D	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
E	PW Cnr	1-10	Attic over radio station	7
E	Plaster	1-5	Covered walk (outside)	2-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

Page 2 of 3

DISTRICT Chico Unified School District DATE July 6, 1994SCHOOL Pleasant Valley Senior INSPECTOR Ron Jones

BLDG.	HOMOG.	ASBESTOS	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
F/G	Plaster	1-5		Covered walk (outdoors)	2-4
F	PW Str	40-60		Rm 55 B/R room	2-4
F	PW Str	40-60		Rm 54 storeroom	7
F	Tank wrap	35-45		B/R room	1-4
F	Debris & PW Cnr	15-20		Attic	2-4
F	Mud jnt	1-10		Room 54 storage	1-4
F	12 jnts	1-10		Small gym	1-4
G	Mud Jnt	1-10		Gym	1-4
H	Plaster	1-5		Covered Walk (outdoors)	1-4
I	Plaster	1-5		Covered Walk (outside)	2-4
I	Trans Wallboard	Assumed		Room 1 - Metal Shop	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
 MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

