

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE July 11, 1997

DATE December 30, 1995

SCHOOL Pleasant Valley High

INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic area (west end)	(7)
A	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
B	PW Cnr	10-15	Attic area	(7)
B	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
C	PW Cnr	1-5	Attic area	1-4
C	Molded blk tabletops	Assumed	Room 20	1-4
C	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
D	PW Cnr	1-10	Attic area	1-4
D	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
E	PW Cnr	1-10	Attic over radio station	1-4
E	Plaster	1-5	Covered walk (outside)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 10, 1995 7-11-97

SCHOOL Pleasant Valley Senior INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
F/G	Plaster	1-5	Covered walk (outdoors)	1-4
F	PW Str	40-60	Rm 55 B/R room	7 07/29/94
F	PW Str	40-60	Rm 54 storeroom	7
F	Tank wrap	35-45	B/R room	7 07/29/94
F	Debris & PW Cnr	15-20	Attic	1-4
F	Mud jnt	1-10	Room 54 storage	7 07/29/94
F	12 jnts	1-10	Small gym	7 07/29/94
G	Mud Jnt	1-10	Gym	7 07/29/94
H	Plaster	1-5	Covered Walk (outdoors)	1-4
I	Plaster	1-5	Covered Walk (outside)	2-4
I	Trans Wallboard	Assumed	Room 1 - Metal Shop	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE December 30, 1995 7-11-97

SCHOOL Pleasant Valley High INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS	
				CODE	COMMENTS
I	12" VFT	1-5	Drafting room	1-4	
J	Lino Yell	30-35	Room 1 Snack Bar	1-4	
J	Lino Brn	25-30	Room 1 Activities room	1-4	
J	Lino Brn	25-30	Stereo storeroom	1-4	

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)