

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No. CAD 981415938

Manifest Document No. 5340

2. Page 1 of 1

Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address
PLEASANT VALLEY HIGH SCHOOL
1475 EAST AVENUE, CHICO, CA. 95928

A. State Manifest Document Number
92775340

4. Generator's Phone (916) 891-3218

B. State Generator's ID
HYHQ 36-029809

5. Transporter 1 Company Name
CALTEC ENVIRONMENTAL, INC.

6. US EPA ID Number
CAD 983612276

C. State Transporter's ID
(916) 821-5083

7. Transporter 2 Company Name

8. US EPA ID Number

E. State Transporter's ID
432331

9. Designated Facility Name and Site Address
ANDERSON SOLID WASTE, INC.
18703 CAMBRIDGE ROAD
ANDERSON, CA. 96007

10. US EPA ID Number
CAD 981388952

F. Transporter's Phone
G. State Facility ID
CAD 981388952
H. Facility's Phone
(916) 347-5236

11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers
No. Type

13. Total Quantity

14. Unit
Wt/Vol

I. Waste Number

a. WASTE ASBESTOS, #9 NA 2212
PG III RQ.

220 BAGS

1018 YRS

State 151

EPA/Other

b.

State

EPA/Other

c.

State

EPA/Other

d.

State

EPA/Other

J. Additional Descriptions for Materials Listed Above

FRIABLE/NONFRIABLE ASBESTOS CONTAINING MATERIAL

K. Handling Codes for Wastes Listed Above

a. 03

b.

c.

d.

15. Special Handling Instructions and Additional Information

TRANSPORTER ADDRESS: 20255 CHARLANNE DRIVE, REDDING, CA. 96002

16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable federal, state and international laws.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

Mary K Leary

Signature

Mary K Leary

Month Day Yr

06 03 99

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

Jeff Rouse

Signature

Jeff Rouse

Month Day Yr

06 29 99

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Yr

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in item 19.

Printed/Typed Name

Rob Roberts

Signature

Rob Roberts

Month Day Yr

06 29 99

DO NOT WRITE BELOW THIS LINE.

92775340
IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802. WITHIN CALIFORNIA, CALL 1-800-424-8802

DISTRICT Chico Unified School District DATE August 11, 1999

SCHOOL Pleasant Valley High INSPECTOR Robert Peters

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic area (west end)	7
A	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
B	PW Cnr	10-15	Attic area	7
B	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
C	PW Cnr	1-5	Attic area	1-4
C	Molded blk tabletops	Assumed	Room 20	1-4
C	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
D	PW Cnr	1-10	Attic area	1-4
D	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
E	PW Cnr	1-10	Attic over radio station	1-4
E	Plaster	1-5	Covered walk (outside)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District DATE August 11, 1999

SCHOOL Pleasant Valley High INSPECTOR Robert Peters

BLDG.	F/G	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
	F	Plaster	1-5	Covered walk (outdoors)	1-4
	F	PW Str	40-60	Rm 55 B/R room	7 07/29/94
	F	PW Str	40-60	Rm 54 storeroom	7
	F	Tank wrap	35-45	B/R room	7 07/29/94
	F	Debris & PW Cnr	15-20	Attic	1-4
	F	Mud jnt	1-10	Room 54 storage	7 07/29/94
	F	12 jnts	1-10	Small gym	7 07/29/94
	G	Mud Jnt	1-10	Gym	7 07/29/94
	H	Plaster	1-5	Covered Walk (outdoors)	1-4
	I	Plaster	1-5	Covered Walk (outside)	5 - Fine cracks
	I	Trans Wallboard	Assumed	Room 1 - Metal Shop	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

DISTRICT Chico Unified School District

DATE 2/26/99

SCHOOL Pleasant Valley High

INSPECTOR Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic area (west end)	7
A	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
B	PW Cnr	10-15	Attic area	7
B	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
C	PW Cnr	1-5	Attic area	1-4
C	Molded blk tabletops	Assumed	Room 20	1-4
C	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
D	PW Cnr	1-10	Attic area	1-4
D	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
E	PW Cnr	1-10	Attic over radio station	1-4
E	Plaster	1-5	Covered walk (outside)	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

POSTED
2/26/99

DISTRICT Chico Unified School District

DATE 2/26/99

SCHOOL Pleasant Valley Senior

INSPECTOR Rob Peters

HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	F/G	HOMOG.	ASBESTOS	MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
	F	Plaster	1-5		Covered walk (outdoors)	1-4
	F	PW Str	40-60		Rm 55 B/R room	7 07/29/94
	F	PW Str	40-60		Rm 54 storeroom	7
	F	Tank wrap	35-45		B/R room	7 07/29/94
	F	Debris & PW Cnr	15-20		Attic	1-4
	F	Mud jnt	1-10		Room 54 storage	7 07/29/94
	F	12 jnts	1-10		Small gym	7 07/29/94
	G	Mud Jnt	1-10		Gym	7 07/29/94
	H	Plaster	1-5		Covered Walk (outdoors)	1-4
	I	Plaster	1-5		Covered Walk (outside)	5 - Fine cracks
	I	Trans Wallboard	Assumed		Room 1 - Metal Shop	1-4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED
MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District

DATE December 30, 1995

9-22-98

SCHOOL Pleasant Valley High

INSPECTOR Rob Jones

Rob Peters

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	PW Cnr	10-15	Attic area (west end)	7 ✓
A	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
B	PW Cnr	10-15	Attic area	7 ✓
B	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
C	PW Cnr	1-5	Attic area	1-4 ✓
C	Molded blk tabletops	Assumed	Room 20	1-4 ✓
C	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
D	PW Cnr	1-10	Attic area	1-4 ✓
D	Plaster	1-5	Covered walk (outdoors)	Retested - no asbestos
E	PW Cnr	1-10	Attic over radio station	1-4 ✓
E	Plaster	1-5	Covered walk (outside)	1-4 ✓

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

