

SIX MONTH SURVEILLANCE HOMOGENEOUS ACBM RECORDS

Date of Inspection: 5/12/03

Inspector: Robert Peters

District: Chico Unified School District

Building: VALHALLA

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" ACT	72	ASSUMED NONE	1,200 S	NORTH & SOUTH ENDS OF VALHALLA CEILING	(1) (12) THE DISTRICT MUST CERTIFY. SAME 05/12/2003	N
M	9" VFT WHITE/BROWN	73	ASSUMED (TRACE)	5,000 S	VALHALLA AREA AND MUSIC ROOM	(1) (12) THE DISTRICT MUST CERTIFY. SAME 05/12/2003	N
S	PLASTER	74	ASSUMED NONE	5,800 S	GIRLS & BOYS RESTROOMS, VALHALLA CEILING, AND KITCHEN WALLS	(1) (12) THE DISTRICT MUST CERTIFY. SAME 05/12/2003	N
					<i>Tested</i>		
<p>NOTE: THIS BUILDING WAS NOT IDENTIFIED IN THE ORIGINAL INSPECTION BY HMS, INC. CERTIFICATION LETTERS MUST BE OBTAINED OR SAMPLING OF MATERIALS MUST OCCUR TO DETERMINE ASBESTOS CONTENT.</p> <p style="text-align: center;">This building was there</p>							

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS



**Forensic Analytical
Analytical Report**

Final FAX

Bulk Asbestos Analysis

(EPA Method 600/R-93-116)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B052332
Date Received: 07/03/03
Date Analyzed: 07/07/03
Date Printed: 07/07/03

Job ID / Site: Parkview Elem. Chico High, *PVHS 10100*

FASI Job ID: 2921-68

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
BR-2 <i>Park View</i>	10248228						
Layer: Stones			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (40%) Fibrous Glass (35%)

BR-3 <i>Parkview</i>	10248229						
Layer: Stones			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (40%) Fibrous Glass (35%)

BR-1 <i>Parkview</i>	10248230						
Layer: Stones			ND				
Layer: Tars			ND				
Layer: Felts			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (Trace%) Fibrous Glass (60%)

PCF-1 <i>Chico High</i>	10248231						
Layer: Off-White Tile			ND				
Layer: Yellow Mastic			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (Trace%)

*C: Mary
Kip
Bob m.
Lab.
CSH bindles (3)
Parkview bindles (3)
Parkview site
PVHS bindles (2)
PVHS file*



Forensic Analytical
Analytical Report

Final FAX

Bulk Asbestos Analysis

(EPA Method 600/R-93-116)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B052332
Date Received: 07/03/03
Date Analyzed: 07/07/03
Date Printed: 07/07/03

Job ID / Site: Parkview Elem. Chico High, *PYHS*

FASI Job ID: 2921-68

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
JR-1 <i>PYHS</i>	10248232						
		Layer: Off-White Sheet Flooring					ND
		Layer: Fibrous Backing					ND

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (20%) Synthetic (15%)

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Results, reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the samples tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.

2921-68

Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

July 2, 2003

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Parkview Elementary, Chico High, Pleasant Valley High

To Whom It May Concern:

Please test the enclosed roof samples from Parkview Elementary, Chico High and Pleasant Valley High for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Parkview Elementary School
Location: Bike Rack Roof
Date Sampled: July 2, 2003
Number of Samples: Three (#BR-1, #BR-2, #BR-3)


Site Sampled: Chico High
Location: Floor - Portable #PC-13
Date Sampled: July 2, 2003
Number of Samples: One (#PCF-1)

Site Sampled: Pleasant Valley High
Location: Unit J Restroom Floor
Date Sampled: July 2, 2003
Number of Samples: One (#JR-1)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor

RP:dlg
Enclosures



Forensic Analytical

BULK SAMPLE REQUEST FORM

CLIENT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE: 7/2/03
	Circle the Method and Turn Around Time 24 hr/12hr/24hr/48hr/Ext	Results Needed:
	PLM: Standard / Point Count	Gravimetry Prep
	TEM: QUAL. / QUANT. / WATER AA/Flame AA/Furnace ICP	
CONTACT: ROBI PETERS		METALS:
P.O.#	JOB #	
SITE: Chico High, Parkview, P.V.H.S		

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
13R-2	7/2	PARKVIEW BIKE RACK ROOF
13R-3	7/2	" " " "
13R-1	7/2	" " " "
PCF-1	7/1/03	CHICO HIGH PORTABLE FLOOR PC-13
JR-1	7/1/03	P.V. RESTROOM FLOOR UNIT 5

Sampled by: ROBI PETERS	Date: 7/2/03 Time: 9:30am
Relinquished by:	Received By: [Signature] 7/3/03 109pm
Date/Time:	Date/Time:
Relinquished by:	Received By:
Date/Time:	Date/Time:
	Sealed Condition (circle one) YES / NO
	Sealed Condition (circle one) YES / NO



Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B052332
Date Received: 07/03/03
Date Analyzed: 07/07/03
Date Printed: 07/07/03
First Reported: 07/07/03

Job ID / Site: Parkview Elem, Chico High, PVHS

FASI Job ID: 2921-68

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
BR-2 Parkview	10248228						
Layer: Stones			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (40%) Fibrous Glass (35%)
Comment: Collected on 07/02/2003

BR-3 Parkview	10248229						
Layer: Stones			ND				
Layer: Black Tar			ND				
Layer: Black Felt			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (40%) Fibrous Glass (35%)
Comment: Collected on 07/02/2003


BR-1 Parkview	10248230						
Layer: Stones			ND				
Layer: Tars			ND				
Layer: Felts			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (Trace%) Fibrous Glass (60%)
Comment: Collected on 07/02/2003

*C: Mary
Kip
Bob M.
Rob
Bundles (2ea)
dier (1ea)*

PCF-1 Chico High	10248231						
Layer: Off-White Tile			ND				
Layer: Yellow Mastic			ND				

Total Composite Values of Fibrous Components: Asbestos:(ND)
Cellulose (Trace%)
Comment: Collected on 07/01/2003





Bulk Asbestos Analysis

(EPA Method 600/R-93-116, Visual Area Estimation)

Chico Unified School Dist
Rob Peters

2455 Carmichael Drive
Chico, CA 95928

Client ID: 2921
Report Number: B052332
Date Received: 07/03/03
Date Analyzed: 07/07/03
Date Printed: 07/07/03
First Reported: 07/07/03

Job ID / Site: Parkview Elem, Chico High

FASI Job ID: 2921-68

Sample Number	Lab Number	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer	Asbestos Type	Percent in Layer
JR-1 - PVA5	10248232						
Layer: Off-White Sheet Flooring						ND	
Layer: Fibrous Backing						ND	

Total Composite Values of Fibrous Components: **Asbestos:(ND)**
 Cellulose (20%) Synthetic (15%)
 Comment: Collected on 07/01/2003

James Flores, Laboratory Supervisor, Hayward Laboratory

Note: Limit of Quantification ('LOQ') = 1%. 'Trace' denotes the presence of asbestos below the LOQ. 'ND' = 'None Detected'.

Analytical results and reports are generated by Forensic Analytical at the request of and for the exclusive use of the person or entity (client) named on such report. Reports or copies of same will not be released by Forensic Analytical to any third party without prior written request from client. This report applies only to the sample(s) tested. Supporting laboratory documentation is available upon request. This report must not be reproduced except in full, unless approved by Forensic Analytical. The client is solely responsible for the use and interpretation of test results and reports requested from Forensic Analytical. This report must not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. Government. Forensic Analytical is not able to assess the degree of hazard resulting from materials analyzed. Forensic Analytical reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. All samples were received in acceptable condition unless otherwise noted.



BULK SAMPLE REQUEST FORM

CLIENT NAME & ADDRESS: 2921 Chico Unified School District 2455 Carmichael Drive Chico, CA 95928	PHONE: (916) 891- FAX: (916) 891-3190	DATE: 7/2/03
	Circle the Method and Turn Around Time 24 hr/12hr/4hr/48hr/Ext	Results Needed:
	PLM: Standard / Point Count	Gravimetry Prep
CONTACT: ROIB PETERS		TEM: QUAL. / QUANT. / WATER
P.O.#	JOB #	AA/Flame AA/Furnace ICP
SITE: Chico High, Parkview, PVHS		METALS:

SAMPLE NUMBER	DATE COLLECTED	SAMPLE LOCATION/DESCRIPTION
13R-2	7/2	PARKVIEW BIKE RACK ROOF
13R-3	7/2	" " " "
13R-1	7/2	" " " "
PCF-1	7/1/03	CHICO HIGH PORTABLE FLOOR. PC-13
JR-1	7/1/03	P.V. RESTROOM FLOOR UNIT 5

Sampled by: ROIB PETERS	Date: 7/2/03 Time: 9:30am
Relinquished by:	Received By: [Signature] 7/3/03 109pm
Date/Time:	Date/Time:
Relinquished by:	Sealed Condition (circle one) YES / NO
Date/Time:	Received By:
Date/Time:	Date/Time:
Relinquished by:	Sealed Condition (circle one) YES / NO

2921-68
Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

July 2, 2003

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Parkview Elementary, Chico High, Pleasant Valley High

To Whom It May Concern:

Please test the enclosed roof samples from Parkview Elementary, Chico High and Pleasant Valley High for asbestos. We would like a 24-hour turnaround on the samples. Please fax the results to us as soon as soon as they are available. Our fax number is (530) 891-3190.

Site Sampled: Parkview Elementary School
Location: Bike Rack Roof
Date Sampled: July 2, 2003
Number of Samples: Three (#BR-1, #BR-2, #BR-3)

Site Sampled: Chico High
Location: Floor – Portable #PC-13
Date Sampled: July 2, 2003
Number of Samples: One (#PCF-1)

Site Sampled: Pleasant Valley High
Location: Unit J Restroom Floor
Date Sampled: July 2, 2003
Number of Samples: One (#JR-1)

Samples Taken by: Rob Peters

Thank you for your prompt response to this request.

Sincerely,



Rob Peters
Maintenance/Operations Supervisor


RP:dlg
Enclosures

CERTIFICATION OF COMPLIANCE FOR BUILDING MATERIALS

This is to certify, in accordance with the Environmental Protection Agency requirements, that the materials and equipment used in the construction of the: _____
Pleasant Valley High Sch for the Chico Unified School
District of Butte County, California, are asbestos free and are, therefore, not subject to monitoring for asbestos contamination.

Project Name: Pleasant Valley High School
Address: 1475 East Ave
Chcio, CA 95973

Contractor: Don C. George, Inc dba George Roofing
Address: 6810 Lincoln Blvd
Oroville, CA 95966-7716

Signature: 
Title: President

SEPARATE CERTIFICATE IS REQUIRED FOR EACH SITE