

**ENTEK CONSULTING GROUP, INC.
ASSESSMENT OF TSI and/or FRIABLE MATERIAL**

District: Chico Unified School District

Date: July 13, 2010

School: Pleasant Valley High School

Inspector: Jack DeLay

Building & Location(s): E - Rooms 1-3, Attic Area of Classroom 3

ECG-

% Asbestos-1-10%

Homogeneous Mat. #5

Material description: Pipe Wrap Corner

Total amount of material this location: 10 L

Amount of friable material this location: 10 L

Damage	Local		Distributed		Damaged	0%
Type of Damage	Air Erosion		Water		Flaking	
	Deterioration		Physical		Delamination	

Probable cause(s) of damage: Physical Damage

POTENTIAL FOR DISTURBANCE				RESPONSE ACTIONS		PREVENTIVE MEASURES	
	H	M	L	Isolate/Restrict	X	Fix leaks	
Accessibility	X			Repair/Cleanup		Prevent water contact	X
Vibration		X		Enclose		Do not drill, cut, sand, or grind	X
Air Erosion			X	Remove	X	Do not affix signs	
Water			X	Encapsulate		Avoid contact	X
Occupancy	X			O & M	X		

Assessment of Material Condition

Significantly Damaged
(Poor)

Damaged
(Fair)

Not damaged
(Good)

Potential Damage: High

High Mod Low

High Mod Low

Hazard Ranking:

1 2 3 4 5 6 7

						X		
--	--	--	--	--	--	---	--	--

Comments & Observations: