

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:
Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 7032
Date Received: 04/04/88
Date Examined: 04/10/88

Lab Number: 8809038
Sample Number: RSD-13
Site: Rosedale Elementary

Analyst: MF

Location: Unit F, Room 1 - acoustical ceiling panel.

P.O.: Rosedale

Gross Description: Off-white fibrous ceiling tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

<1
<1
<1

%
%
%
%

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Mineral Wool
Polyethylene

15-20
55-60
<1

%
%
%
%

70-80 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates
Perlite

5-10
15-20

%
%
%
%

20-30 %

Analyst:

Michelle J. Fay

Supervisor:

do

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809039
Sample Number: RSD-14
Site: Rosedale Elementary

Analyst: MF

Location: Unit F - linoleum flooring and backing.

P.O.: Rosedale

Gross Description: White linoleum floor tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile

<1

%

Amosite

<1

%

Crocidolite

<1

%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

30-35 %

Cellulose

30-35

%

Mineral Wool

<1

%

Polyethylene

<1

%

Synthetic Fibers

Trace

%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

65-70 %

Unspecified Particulates

65-70

%

%

%

%

Analyst:

Michelle J. Fox

Supervisor:

de

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809040
Sample Number: RSD-15
Site: Rosedale Elementary

Analyst: MF

Location: Unit G, Room 14 - 9" VFT - white and adhesive.

P.O.: Rosedale

Gross Description: Off-white floor tile assoc with black tar adhesive. (Asbestos in both)

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile	15-20	%
Amosite	<1	%
Crocidolite	<1	%

15-20 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose	<1	%
Mineral Wool	<1	%
Polyethylene	<1	%

<1 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates	80-85	%
--------------------------	-------	---

80-85 %

Analyst:

Michelle J. Fox

Supervisor:

de

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

Client: FOR
Hazard Management Services, Inc.

P.O. Box 7012
Modesto, CA 95355

Client Number: 146
Report Number: 7032
Date Received: 04/04/88
Date Examined: 04/11/88

Analyst: MF

Lab Number: 8809041
Sample Number: RSD-16
Site: Rosedale Elementary

Location: Unit 6, Room 3 - 12" square acoustical ceiling tile.

P.O.: Rosedale

Gross Description: Off-white fibrous ceiling tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

<1
<1
<1

<1

%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Mineral Wool
Polyethylene

90-95
<1
<1

90-95

%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

5-10

5-10

%

Analyst: Michelle J. Fox

Supervisor: DD

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

3777 Depot Road, Suite 408, Hayward, CA 94545 • (415) 887-8828

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809043
Sample Number: RSD-18
Site: Rosedale Elementary

Analyst: MF

Location: Portable Unit I, Room 21 - 12" VFT - white.

P.O.: Rosedale

Gross Description: Off-white floor tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile

<1

<1

%

Amosite

<1

Crocidolite

<1

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose

Trace

Trace

%

Mineral Wool

<1

Polyethylene

<1

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

98-99

98-99

%

Analyst:

Michelle Fox

Supervisor:

[Signature]

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809044
Sample Number: RSD-19
Site: Rosedale Elementary

Analyst: MF

Location: Portable Unit I, Room 21 - ceiling panels.

P.O.: Rosedale

Gross Description: Off-white fibrous ceiling tile.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

Chrysotile

<1

%

Amosite

<1

%

Crocidolite

<1

%

<1

%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose

10-15

%

Mineral Wool

60-65

%

Polyethylene

<1

%

70-80

%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

5-10

%

Perlite

15-20

%

20-30

%

Analyst:

Michelle Fox

Supervisor:

MF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

5777 Depot Road, Suite 408, Hayward, CA 94545 • (415) 887-8828

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809045
Sample Number: RSD-20A
Site: Rosedale Elementary

Analyst: MF

Location: Unit 6, Men's Bathroom - hard plaster wall.

P.O.: Rosedale

Gross Description: Off-white plaster powder.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

1-5 %

Cellulose	1-5	%
Mineral Wool	Trace	%
Polyethylene	<1	%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

95-99 %

Unspecified Particulates	95-99	%
--------------------------	-------	---

Analyst:

Michelle J. Fox

Supervisor:

de

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809046
Sample Number: RSD-20B
Site: Rosedale Elementary

Analyst: MF

Location: Unit 6, Men's Bathroom - hard plaster ceiling.

P.O.: Rosedale

Gross Description: Off-white plaster powder.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Trace %

Cellulose	Trace	%
Mineral Wool	Trace	%
Polyethylene	<1	%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

98-99 %

Unspecified Particulates	98-99	%
--------------------------	-------	---

Analyst:

Michelle J. Fox

Supervisor:

JD

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809047
Sample Number: RSD-20C
Site: Rosedale Elementary

Analyst: MF

Location: Unit 6, Women's Bathroom - hard plaster wall.

P.O.: Rosedale

Gross Description: Off-white plaster powder.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile	<1	%
Amosite	<1	%
Crocidolite	<1	%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Trace %

Cellulose	Trace	%
Mineral Wool	Trace	%
Polyethylene	<1	%

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

98-99 %

Unspecified Particulates	98-99	%
--------------------------	-------	---

Analyst:

Michelle J. Fox

Supervisor:

MF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

Forensic Analytical Specialties, Inc.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

BULK ASBESTOS ANALYSIS REPORT

FOR

Client:

Hazard Management Services, Inc.

P.O. Box 7012

Modesto, CA 95355

Client Number: 146

Report Number: 7032

Date Received: 04/04/88

Date Examined: 04/11/88

Lab Number: 8809048

Analyst: MF

Sample Number: RSD-21

Site: Rosedale Elementary

Location: Unit H, Bathroom - linoleum.

P.O.: Rosedale

Gross Description: Off-white linoleum tile assoc. with fibrous backing.

MICROSCOPIC DESCRIPTION:

TOTAL ASBESTOS PRESENT:

<1 %

Chrysotile

<1 %

Amosite

<1 %

Crocidolite

<1 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

15-20 %

Cellulose

5-10 %

Mineral Wool

1-5 %

Polyethylene

<1 %

Synthetic Fibers

1-5 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

80-90 %

Unspecified Particulates

80-90 %

Analyst:

Michelle J. Fox

Supervisor:

MF

COMMENTS: Analysis employs Polarized Light Microscopy with Dispersion Staining, and is performed by an analyst qualified under the EPA bulk asbestos proficiency testing program. Samples with no observable asbestiform minerals are designated as containing less than one percent (<1%) asbestos. Samples in which asbestiform minerals have been observed, but exist in concentrations of less than one percent (<1%) are designated as present in "trace" amounts.

PROJ SD-1A

SIGNATURE-
1-23-09

DATE _____


APPLICATION NO.

SITE SUMMARY


GRADES SERVED AT THIS SCHOOL

[illegible]


PREPARED BY: THOMSON & HENDRICKS, ARCHITECTS AND PLANNERS, 60 DECLARATION DR., CHICO, CALIFORNIA 95926 (916) 342-5669



Rosedale Elementary
Inspected 3/31/88



Rosedale Elementary
Unit A
Boiler room (rm #3)



Rosedale Elementary
Unit A
Boiler room(rm #3)

Inspection Form I-1

DISTRICT Chico Unified
 SCHOOL Rosedale
 Building Unit D
 Location Room 17 Storage Room
 (functional area)

Page of
 Date 3-31-88
 Inspector
 HMS- RSD-07

Material: Surfacing TSI Misc. % Asbestos 1-5
 Description pipewrap corner storage area off MPR
 Amount of Material (NF) F 2/0 (ft²) (1f) Assumed ACM: Y / N # of samples 1

CONDITION: % damaged: 0% <1% 1-10% 11-25% >25% none local distributed

Type damage: air; deterioration; water; physical; flaking

DESCRIPTION: Very good shape of mudded joints attached to aircell straight sections of compressor unit.

POTENTIAL FOR DISTURBANCE:

Accessibility: H (M) L
 Vibration : (H) M L
 Air Erosion : H M (L)
 Water : H M (L)

PREVENTATIVE MEASURES:

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact


COMMENTS:

Storage area of chairs.
Limit storage or physical contact.

REMEDIAL ACTIONS

isolate/restrict repair/cleanup
 enclose encapsulate
 remove O&M

ACBM Condition - Assessment



Inspection Form I-1

DISTRICT Chico UnifiedPage of SCHOOL RosedaleDate 3-31-88Building Unit DInspector RBLocation Room 17 Storage Room of f
(functional area) MVRHMS RSD-06Material: Surfacing (TST) Misc. % Asbestos 1-5
Description pipe wrap straight cell ODAmount of Material (NF) F 15/0 (ft²/(F)) Assumed ACM: Y / N # of samples 1

CONDITION: % damaged: Extent of damage:

0% <1% 1-10% 11-25% >25% none local distributed

Type damage: air; deterioration; water; physical; flaking

DESCRIPTION: Pipe wrap in very good shape. Some cracking
at hanger uprint - wrapped pipe for compressor unit.
Vibration each time compressor turns on.

POTENTIAL FOR DISTURBANCE:

PREVENTATIVE MEASURES:

Accessibility: H (M) L
Vibration : (H)
Air Erosion : H (M) (L)
Water : H (M)

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact


COMMENTS: Storage area for
chairs.
Some visible cracks present
due to vibration.Two cracks should be re-wrapped
(minor)REMEDIAL ACTIONS
isolate/restrict repair/cleanup

enclose encapsulate

remove

O&M

ACBM Condition - Assessment



HAZARD MANAGEMENT SERVICES, INC.

Inspection Form I-1

DISTRICT Chicago Unified
 SCHOOL Rosedale
 Building Unit G
 Location Room 14 Classroom
 (functional area)

Page of Date 3-31-88Inspector RB

HMS-RSD-15

Material: Surfacing TSI Misc. % Asbestos 15-20
 Description 9" white UFT

Amount of Material (NF / F) 6500 (ft²) lf) Assumed ACM: Y / N # of samples 1

CONDITION: % damaged:

Extent of damage:

0% <1% 1-10% 11-25% >25%

none local distributed

Type damage: air; deterioration; water; physical; flaking

DESCRIPTION: Excellent shape of floor tile

POTENTIAL FOR DISTURBANCE:

Accessibility: H M L
 Vibration : H M L
 Air Erosion : H M L
 Water : H M L

PREVENTATIVE MEASURES:

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact

COMMENTS:

REMEDIAL ACTIONS

isolate/restrict repair/cleanup


enclose

encapsulate

remove

O&M

ACBM Condition - Assessment



DISTRICT Chico Unified Inspection Form I-1Page of SCHOOL RosedaleDate 3-31-88Building Unit CInspector RBLocation Room 1 Classroom #1
(functional area)HMS-RSD-09Material: Surfacing TSI Misc % Asbestos 1-5
Description Beige 9" VFTAmount of Material (NF) / F (ft²/lf) Assumed ACM: Y / N # of samples 1

CONDITION: % damaged: Extent of damage:

0% <1% 1-10% 11-25% >25% none local distributedType damage: air; deterioration; water; physical; flakingDESCRIPTION: Floor tile in very good shape. Some areas
with chipped tile

POTENTIAL FOR DISTURBANCE:

Accessibility:	<u>H</u>	M	L
Vibration	: H	M	<u>L</u>
Air Erosion	: H	M	<u>L</u>
Water	: H	M	<u>L</u>

PREVENTATIVE MEASURES:

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact

COMMENTS:

REMEDIAL ACTIONS

isolate/restrict repair/cleanup

enclose

encapsulate

remove

O&M

ACBM Condition - Assessment

Poor
(Significant damage)

Fair

Good
(little or no damage)Hazard
Rank 1

(Damaged)

Potential Disturbance

Potential Damage

High
Potential
Significant
DamageModerate
Potential
Damage

Low

Hazard
Rank 2Hazard
Rank 3Hazard
Rank 4High
Potential
Significant
DamageHazard
Rank 5Moderate
Potential
DamageHazard
Rank 6

Low

Hazard
Rank 7

Inspection Form I-1

DISTRICT Chico Unified
 SCHOOL Rosedale
 Building Unit D
 Location 19 Hallway
 (functional area)

Page of Date 3-31-88Inspector RBHMS-RSD-03

Material: Surfacing TSI Misc. % Asbestos 5-10
 Description 9" Green VFT

Amount of Material (NF) F) (ft²/lf) Assumed ACM: Y / N # of samples 1

CONDITION: % damaged: Extent of damage:
 0% <1% 1-10% 11-25% >25% none local distributed

Type damage: air; deterioration; water; physical flakingDESCRIPTION: Floor tile in excellent shape

POTENTIAL FOR DISTURBANCE:

Accessibility: H M L
 Vibration : H M L
 Air Erosion : H M L
 Water : H M L

PREVENTATIVE MEASURES:

1. Fix Leaks
2. Prevent water contact
- 3 Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact

COMMENTS:

REMEDIAL ACTIONS


isolate/restrict repair/cleanup

enclose encapsulate

remove

O&M

ACBM Condition - Assessment



DISTRICT Albino unified Inspection Form I-1

SCHOOL Rosedale

Date 3-31-88

Building Unit D offices

Inspector *RB*

Location Room 10 Conference Rm.
(functional area)

HMS-RSD-01A,B,C,D,E,F,G

Material:	Surfacing	TSI	Misc.	% Asbestos	1.5
Description	Hard ceiling plaster Course GWT.				

Amount of Material (NF / F) _____ (ft²/lf) Assumed ACM: Y / N samples

<u>CONDITION:</u>		<u>% damaged:</u>		<u>Extent of damage:</u>	
<u>0%</u>	<1%	1-10%	11-25%	>25%	
				<u>none</u>	local distributed

Type damage: air; deterioration; water; physical; flaking

DESCRIPTION: Excellent shape

POTENTIAL FOR DISTURBANCE:

Accessibility:	H	M	L
Vibration	: H	M	L
Air Erosion	: H	M	L
Water	: H	M	L

PREVENTATIVE MEASURES:

1. Fix Leaks
2. Prevent water contact
3. Do not DCSG
4. Do not affix signs/deco's
5. Avoid contact

COMMENTS: _____


REMEDIAL ACTIONS

isolate/restrict repair/cleanup

enclose encapsulate

remove O&M

ACBM Condition - Assessment



Please print or type. (Form designed for use on elite (12-pitch typewriter).)

89437883

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.	Manifest Document No.	2. Page 1 of	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address Chico Unified School District 1183 Seventh Street Chico, CA 95928		6. US EPA ID Number CAD120894497		A. State Manifest Document Number 89437883	
4. Generator's Phone (916) 891-3000		7. Transporter 2 Company Name		B. State Generator's ID HY1H1316101000	
5. Transporter 1 Company Name APC Contractors, Inc.		8. US EPA ID Number		C. State Transporter's ID 905916	
9. Designated Facility Name and Site Address COWSPO, Inc. Landfill 9999 Austin Rd. Stockton, CA 95203		10. US EPA ID Number CAD990794133		D. Transporter's Phone (209) 441-7650	
				E. State Transporter's ID	
				F. Transporter's Phone	
				G. State Facility's ID CAD990794133	
				H. Facility's Phone (209) 982-4298	
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers No.	Type	13. Total Quantity	14. Unit Wt/Vol
a. RC, Hazardous Waste Solid NOS, ORM-E, NA9185 (Asbestos)		0216	BA	0190105	
b. RC, Hazardous Waste solid NOS, ORM-E, NA9189 (Asbestos)		050	BF	0010117	
c.					
d.					
J. Additional Descriptions for Materials Listed Above 100% Asbestos Waste Mixture		K. Handling Codes for Wastes Listed Above a. 00 b. 02 c. d.			
15. Special Handling Instructions and Additional Information Project: Rosedale Elementary School DO NOT BREAK BAGS OR CAUSE DUST. AVOID BREATHING DUST BURY SEPARATELY AND COVER WITH SACKFILL					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.					
Printed/Typed Name ROBERT PETERS		Signature Robert Peters		Month Day Year 10/12/1989	
17. Transporter 1 Acknowledgement of Receipt of Materials					
Printed/Typed Name John Schmedele		Signature John Schmedele		Month Day Year 10/12/1989	
18. Transporter 2 Acknowledgement of Receipt of Materials					
Printed/Typed Name		Signature		Month Day Year	
19. Discrepancy Indication Space					
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.					
Printed/Typed Name DAVID H. DUNKLEY		Signature David H. Dunkley		Month Day Year 10/12/1989	

Print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

Manifest Document No.

2. Page 1 of

Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address

Chico Unified School District
1103 Seventh Street, Chico, CA 95928
4. Generator's Phone (916) 851-2000

A. State Manifest Document Number

89437883

B. State Generator's ID

C. State Transporter's ID 003916

D. Transporter's Phone 209-441-7291

5. Transporter 1 Company Name

APC Contractors, Inc.

6. US EPA ID Number

CAD170894197

7. Transporter 2 Company Name

8. US EPA ID Number

E. State Transporter's ID

F. Transporter's Phone

9. Designated Facility Name and Site Address

Perwardis Ind. Landfill
9999 Austin Rd.
Scottsbluff, NE 68903

10. US EPA ID Number

CAD990794193

G. State Facility's ID

CAD990794193

H. Facility's Phone

(209) 982-4295

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers
No. Type

13. Total Quantity

14. Unit
Wt/Vol

I. Waste No.

a. RC Hazardous Waste Solid
NOS ORM-E, H43188 (Asbestos)

026

GA

0100105

State 51

EPA/Other

b. RC Hazardous Waste Solid
NOS ORM-E, H43188 (Asbestos)

050

DF

000117

State 51

EPA/Other

c.

State

EPA/Other

d.

State

EPA/Other

J. Additional Descriptions for Materials Listed Above

100% Asbestos Waste Mixture

K. Handling Codes for Wastes Listed Above

a. 03

b. 03

c.

d.

15. Special Handling Instructions and Additional Information

Project: Rosedale Elementary School
DO NOT BREAK BAGS OR CAUSE DUST. AVOID BREATHING DUST.
SIFT SEPARATELY AND COVER WITH BACKFILL

16.

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

Signature

Month Day Year

ROBERT PETERS

Robert Peters

10/21/89

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

John Schmedene

John A. Schmedene

10/21/89

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

Signature

Month Day Year

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

Please print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. CAD9931415870		Manifest Document No.		2. Page 1 of		Information in the shaded areas is not required by Federal law.					
3. Generator's Name and Mailing Address Chico Unified School District 1193 Seventh Street Chico, CA 95928						A. State Manifest Document Number 89437805							
						B. State Generator's ID HY HQ 36-329809							
4. Generator's Phone (916) 891-3000						C. State Transporter's ID 303915							
5. Transporter 1 Company Name APC Contractors, Inc.						D. Transporter's Phone (916) 441-1591							
6. US EPA ID Number CAD120804497						E. State Transporter's ID							
7. Transporter 2 Company Name						F. Transporter's Phone							
8. US EPA ID Number						G. State Facility's ID CAD990794133							
9. Designated Facility Name and Site Address Forward, Inc. Landfill 9999 Austin Rd. Stockton, CA 95203						H. Facility's Phone (209) 982-4298							
10. US EPA ID Number CAD990794133													
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)						12. Containers		13. Total Quantity		14. Unit Wt/Vol		1. Waste No.	
						No. Type							
a. RC, Hazardous Waste Solid NOS, ORM-E, NAB189 (Asbestos)						0678		BA		0010105		State 51	
												EPA/Other	
b. RC, Hazardous Waste Solid NOS, ORM-E, NAB189 (Asbestos)						0025		DF		000008		State 51	
												EPA/Other	
c.												State	
												EPA/Other	
d.												State	
												EPA/Other	
J. Additional Descriptions for Materials Listed Above 100% Asbestos Waste Mixture						K. Handling Codes for Wastes Listed Above							
						a. 03 b. 03							
15. Special Handling Instructions and Additional Information Project: Rosedale Elementary School BURY SEPARATELY AND COVER WITH BACKFILL						c.							
						d.							
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.													
Printed/Typed Name ALAN OTTO					Signature <i>Alan Otto</i>			Month Day Year 07/20/89					
17. Transporter 1 Acknowledgement of Receipt of Materials													
Printed/Typed Name John Schmaladeke					Signature <i>John Schmaladeke</i>			Month Day Year 10/12/189					
18. Transporter 2 Acknowledgement of Receipt of Materials													
Printed/Typed Name					Signature			Month Day Year					
19. Discrepancy Indication Space													
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.													
Printed/Typed Name Richard CARLILL					Signature <i>Richard Carlill</i>			Month Day Year 10/12/89					

89437805

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL TOXIC SUBSTANCE CENTER. 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

89437805

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8602; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

7099814 5870

Manifest Document No.

2. Page 1 of

Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address

Chico Unified School District
1182 Seventh Street Chico, CA 95328

4. Generator's Phone ()

(530) 891-3000

5. Transporter 1 Company Name

ABC Contractors, Inc

6. US EPA ID Number

CAD100004893

7. Transporter 2 Company Name

8. US EPA ID Number

9. Designated Facility Name and Site Address

FORWARD, INC. Landfill
9900 Austin Rd
Stockton, CA 95203

10. US EPA ID Number

CAD1000794133

A. State Manifest Document Number

89437805

B. State Generator's ID

NY HC 35-0199008

C. State Transporter's ID

D. Transporter's Phone

E. State Transporter's ID

F. Transporter's Phone

G. State Facility's ID

CAD100794133

H. Facility's Phone

(209) 981-4298

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers
No. Type

13. Total Quantity

14. Unit
Wt/Vol

15. Waste No.

a. RC Hazardous Waste Solid
NOS. ORM-E; NA9129 (Asbestos)

028

1

001005

b. RC Hazardous Waste Solid
NOS. ORM-E; NA9129 (Asbestos)

025

1

000018

c.

1

1

1

d.

1

1

1

J. Additional Descriptions for Materials Listed Above

100% Asbestos Waste Mixture

K. Handling Codes for Wastes Listed Above

a. 00

b. 00

c.

d.

15. Special Handling Instructions and Additional Information

Project: Rosedale Elementary School

SHIPP SEPARATELY AND COVER WITH BACKFILL

16.

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

ALAN OTTO

Signature

Alan Otto

Month Day Year

10/12/89

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

John Salvendy

Signature

John Salvendy

Month Day Year

10/12/89

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

Signature

Month Day Year

Please print or type. (Form designed for use on elite (12-pitch typewriter).)

89437804

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL HAZARDOUS WASTE CENTER 1-800-424-8802, WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. AD981415370	Manifest Document No.	2. Page 1 of	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address Chico Unified School District 1163 Seventh Street Chico, CA 95928				A. State Manifest Document Number 89437804	
4. Generator's Phone (916) 891-3000				B. State Generator's ID HY/HO/36-029809/1/1	
5. Transporter 1 Company Name APC Contractors, Inc.		6. US EPA ID Number CA01P01804197		C. State Transporter's ID 903916	
7. Transporter 2 Company Name		8. US EPA ID Number		D. Transporter's Phone (209) 441-7971	
9. Designated Facility Name and Site Address Forward, Inc. Landfill 9999 Austin Rd. Stockton, CA 95203		10. US EPA ID Number CA0990794133		E. State Transporter's ID	
				F. Transporter's Phone	
				G. State Facility's ID CA0990794133	
				H. Facility's Phone (209) 982-4298	
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)			12. Containers No. Type	13. Total Quantity	14. Unit Wt/Vol
a. RC, Hazardous Waste Solid NOS, ORM-E, NA9189 (Asbestos)			Q12 1	900102	Y
b. RC, Hazardous Waste solid NOS, ORM-E, NA9189 (Asbestos)			038 1	900113	Y
c.					
d.					
J. Additional Descriptions for Materials Listed Above 100% Asbestos Waste Mixture			K. Handling Codes for Wastes Listed Above		
			a. 02 b. 02		
			c. d.		
15. Special Handling Instructions and Additional Information Project: Rosedale Elementary School BURY SEPARATELY AND COVER WITH BACKFILL					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.					
Printed/Typed Name ROBERT PETERS		Signature Robert Peters		Month Day Year 10/7/17/89	
17. Transporter 1 Acknowledgement of Receipt of Materials					
Printed/Typed Name John Schmiedekne		Signature John C. Schmiedekne		Month Day Year 07/17/89	
18. Transporter 2 Acknowledgement of Receipt of Materials					
Printed/Typed Name		Signature		Month Day Year	
19. Discrepancy Indication Space					
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.					
Printed/Typed Name DAVID H. DEANNEY		Signature David H. Deanney		Month Day Year 10/7/17/89	

89437804

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL HAZARDOUS WASTE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

Please print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.	Manifest Document No.	2. Page 1 of	Information in the shaded areas is not required by Federal law.
3. Generator's Name and Mailing Address Chico Unified School District 1133 34th Street Chico, CA 95928				A. State Manifest Document Number 89437804	
4. Generator's Phone (415) 391-2000				B. State Generator's ID HY MD 35-019899	
5. Transporter 1 Company Name ABC Companies Inc.		6. US EPA ID Number 015000000000000000		C. State Transporter's ID 903916	
7. Transporter 2 Company Name		8. US EPA ID Number		D. Transporter's Phone 209 441-5971	
9. Designated Facility Name and Site Address Forward, Inc. Landfill 9999 Austin Rd Brookland, CA 95203		10. US EPA ID Number 010000000000000000		E. State Transporter's ID	
				F. Transporter's Phone	
				G. State Facility's ID CAG990794 33	
				H. Facility's Phone (209) 982-4298	
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)				12. Containers No. Type	13. Total Quantity
a. RC, Hazardous Waste Solid NOS, ORM-E, NA3136 (Asbestos)				912 1	909102
b. RC, Hazardous Waste Solid NOS, ORM-E, NA3136 (Asbestos)				032 1	99013
c.					
d.					
J. Additional Descriptions for Materials Listed Above 100% Asbestos Waste Mixture				K. Handling Codes for Wastes Listed Above a. 00 b. 00 c. d.	
15. Special Handling Instructions and Additional Information Prohibit: Resealable Elementary School SEAL SEPARATELY AND COVER WITH BACKFILL					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.					
Printed/Typed Name ROBERT PETERS		Signature <i>Robert Peters</i>		Month Day Year 07 11 89	
17. Transporter 1 Acknowledgement of Receipt of Materials					
Printed/Typed Name John C. Schmitt		Signature <i>John C. Schmitt</i>		Month Day Year 07 11 89	
18. Transporter 2 Acknowledgement of Receipt of Materials					
Printed/Typed Name		Signature		Month Day Year	
19. Discrepancy Indication Space					
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.					
Printed/Typed Name		Signature		Month Day Year	