

July 14, 1997
~~January 9, 1998~~

DISTRICT Chico Unified School District DATE January 9, 1998

SCHOOL Rosedale Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
A	Ceill Plas	1-5	Room 2, both RR	(7)
A	Mud Jnts	70-75	Room 3, Boiler Room	(7)
B	Ceill Plas	1-5	Room 9 & 7, Lounge & RR	(7)
B	9" VFT Bg	1-5	Room 1 (5 classrooms)	(7)
C	9" VFT Bg	1-5	Room 1 (5 classrooms)	(7)
D	Ceill Plas	1-5	Unit D all rooms except Kitchen area	(7)
D	9" VFT Gn	5-10	Rm 15,17,16,18,	(1) (4)
D	9" VFT Gn	5-10	Rm 20,19,10,11,12,13	(7)
D	PW Debris	65-70	Rm 19 access to radiator	(7)
D	PW Str 4"	1-5	Rm 17 storage (MP)	(7)
D	PW Cnr	1-5	Rm 17 storage (MP)	(7)

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)

SIX-MONTH SURVEILLANCE

DISTRICT Chico Unified School District DATE January 9, 1998 7-11-97

SCHOOL Rosedale Elementary INSPECTOR Ron Jones

BLDG.	HOMOG. MAT.#	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	9" VFT Gn	5-10	MPR, Kitchen, Food Services, Kitchen Storage	(1) (4)
D	4" PW Str	1-5	Room 18 Water Heater Closet	(1) (4)
D	Tran Pipe	Assumed	Room 18 Water Heater Closet	(1) (4)
E	9" VFT Bg	1-5	Rm 2 A&B, Rms 1 & 3	(7)
E	9" VFT Wh	15-20	Rm 14 and classrooms	(1) (4)
E	9" VFT Wh	1-5	Library Workroom	(7) 12/94

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (25% OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES (IF YES, EXPLAIN UNDER COMMENTS)

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

MISC: (11) INACCESSIBLE, NO SURVEILLANCE DATA (12) OTHER (EXPLAIN UNDER COMMENTS)