

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/07/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
					<b>Reconstruction Completed - Need Letter</b>	BUILDING A - BURNED DOWN 10-06-00. PRESENTLY UNDER CONSTRUCTION.	

School: Shasta Elementary

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	1	NONE DETECTED	4,500 S	LIBRARY AND CLASSROOMS 5, 6, 9, & 10	(13) REPRESENTED BY SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	2,500 S	ENTIRE WING	(1) (4) <b>Same</b>	N
M	DRYWALL	80	ASSUMED	1,500 S	GIRLS & BOYS RESTROOMS AND CUSTODIAN ROOM	↓	N
M	TRANSITE PANEL	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

**CONDITION CODE**

**General Condition:** (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
**Change in Condition:** (4) No (5) Yes (If Yes, explain under comments)  
**Abated:** (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
**Miscellaneous:** (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/07/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	FT <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	1	NONE DETECTED	7,000 S	OFFICE AND CLASSROOMS 7, 8, 11, 12, & 13	(13) SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	600 S	OFFICE	(1) (4) Same - Carpet over tile principal office & part of main office.	N
S	PLASTER	86	ASSUMED	250 S	GIRLS & BOYS RESTROOM CEILINGS	(1) Same	N
M	TRANSITE PANELS	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4) Same	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/07/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: PORTABLES 19 - 22

Material Class	Material	Homo. Mat. #	% Asb.	FT <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	88	ASSUMED	3,200 S	PORTABLES 19 - 22	(1) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N
M	12" VFT WHITE/BLUE	89	ASSUMED	3,200 S	PORTABLES 19 - 22	(1) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N

*Letters on file*

**CONDITION CODE**

- General Condition:** (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
**Change in Condition:** (4) No (5) Yes (If Yes, explain under comments)  
**Abated:** (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
**Miscellaneous:** (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/07/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: PORTABLES 23 - 26

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	87	ASSUMED	3,600 S	PORTABLES 23 - 26	(1) THESE PORTABLES HAVE A 1/98 MFG. DATE. DISTRICT CERTIFICATION REQUIRED.	N
M	DRYWALL	111	ASSUMED	4,000 S	PORTABLES 23 - 26	(11) COULD BE BEHIND TAGBOARD.	N

Same

School: Shasta Elementary

Building: PORTABLES 16, 17, & 18

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	109	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4) Same	N
M	2 X 4 FCP'S	110	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4)	N
M	DRYWALL	111	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4) (11) DRYWALL BEHIND TAGBOARD.	N

Same

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 11/07/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: SPEECH & PORTABLE 14

Material Class	Material	Homo. Mat. #	% Asb.	FT <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	60	ASSUMED	1,400 S	SPEECH & PORTABLE 14	(1) New unit, need letter.	N
M	12" VFT	70	ASSUMED	1,400 S	SPEECH & PORTABLE 14	(11) COULD BE UNDER CARPET.	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
					<b>Reconstruction Completed - Need Letter</b>	BUILDING A - BURNED DOWN 10-06-00, PRESENTLY UNDER CONSTRUCTION.	

School: Shasta Elementary

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	1	NONE DETECTED	4,500 S	LIBRARY AND CLASSROOMS 5, 6, 9, & 10	(13) REPRESENTED BY SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	2,500 S	ENTIRE WING	(1) (4) <b>Same</b>	N
M	DRYWALL	80	ASSUMED	1,500 S	GIRLS & BOYS RESTROOMS AND CUSTODIAN ROOM	↓	N
M	TRANSITE PANEL	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4) ↓	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	1	NONE DETECTED	7,000 S	OFFICE AND CLASSROOMS 7, 8, 11, 12, & 13	(13) SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	600 S	OFFICE	(1) (4) Same	N
S	PLASTER	86	ASSUMED	250 S	GIRLS & BOYS RESTROOM CEILINGS	(1)	N
M	TRANSITE PANELS	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4) Same	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
Change in Condition: (4) No (5) Yes (if Yes, explain under comments)  
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: PORTABLES 19 - 22

Material Class	Material	Homo. Mat. #	% Asb.	FT <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	88	ASSUMED	3,200 S	PORTABLES 19 - 22	(1) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N
M	12" VFT WHITE/BLUE	89	ASSUMED	3,200 S	PORTABLES 19 - 22	(1) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N

*Letters on file*

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**



**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: PORTABLES 23 - 26

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	87	ASSUMED	3,600 S	PORTABLES 23 - 26	(1) THESE PORTABLES HAVE A 1/98 MFG. DATE. DISTRICT CERTIFICATION REQUIRED.	N
M	DRYWALL	111	ASSUMED	4,000 S	PORTABLES 23 - 26	(11) COULD BE BEHIND TAGBOARD.	N

School: Shasta Elementary

Building: PORTABLES 16, 17, & 18

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	109	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4) Same	N
M	2 X 4 FCP'S	110	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4)	N
M	DRYWALL	111	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4) (11) DRYWALL BEHIND TAGBOARD.	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 05/09/2002

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: SPEECH & PORTABLE 14

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	60	ASSUMED	1,400 S	SPEECH & PORTABLE 14	(1) New unit, need letter.	N
M	12" VFT	70	ASSUMED	1,400 S	SPEECH & PORTABLE 14	(11) COULD BE UNDER CARPET.	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS XCBM RECORDS**

Date of Inspection: 01/11/02

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
					<b>Reconstruction Completed - Need Letter</b>	BUILDING A - BURNED DOWN 10-06-00, PRESENTLY UNDER CONSTRUCTION.	

School: Shasta Elementary

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	1	NONE DETECTED	4,500 S	LIBRARY AND CLASSROOMS 5, 6, 9, & 10	(13) REPRESENTED BY SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	2,500 S	ENTIRE WING	(1) (4)	N
M	DRYWALL	80	ASSUMED	1,500 S	GIRLS & BOYS RESTROOMS AND CUSTODIAN ROOM	(1)	N
M	TRANSITE PANEL	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

**CONDITION CODE**

**General Condition:** (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
**Change in Condition:** (4) No (5) Yes (if Yes, explain under comments)  
**Abated:** (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
**Miscellaneous:** (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 01/11/02

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	1	NONE DETECTED	7,000 S	OFFICE AND CLASSROOMS 7, 8, 11, 12, & 13	(13) SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	600 S	OFFICE	(1) (4)	N
S	PLASTER	86	ASSUMED	250 S	GIRLS & BOYS RESTROOM CEILINGS	(1)	N
M	TRANSITE PANELS	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

**CONDITION CODE**

- General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS XCBM RECORDS**

Date of Inspection: 01/11/02

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: PORTABLES 19 - 22

Material Class	Material	Homo. Mat. #	% Asb.	F <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	88	ASSUMED	3,200 S	PORTABLES 19 - 22	(1) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N
M	12" VFT WHITE/BLUE	89	ASSUMED	3,200 S	PORTABLES 19 - 22	(1) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N

*Letters on file*

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS XCBM RECORDS**

Date of Inspection: 01/11/02

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: PORTABLES 23 - 26

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	87	ASSUMED	3,600 S	PORTABLES 23 - 26	(1) THESE PORTABLES HAVE A 1/98 MFG. DATE. DISTRICT CERTIFICATION REQUIRED.	N
M	DRYWALL	111	ASSUMED	4,000 S	PORTABLES 23 - 26	(11) COULD BE BEHIND TAGBOARD.	N

School: Shasta Elementary

Building: PORTABLES 16, 17, & 18

Material Class	Material	Homo. Mat. #	% Asb.	Ft <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT	109	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4)	N
M	2 X 4 FCP'S	110	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4)	N
M	DRYWALL	111	ASSUMED	2,700 S	PORTABLES 16, 17, & 18	(1) (4) (11) DRYWALL BEHIND TAGBOARD.	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**

**SIX MONTH SURVEILLANCE  
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 01/11/02

District: Chico Unified School District

Inspector: Robert Peters

School: Shasta Elementary

Building: SPEECH & PORTABLE 14

Material Class	Material	Homo. Mat. #	% Asb.	FT <sup>2</sup> /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP'S	60	ASSUMED	1,400 S	SPEECH & PORTABLE 14	(1) New unit, need letter.	N
M	12" VFT	70	ASSUMED	1,400 S	SPEECH & PORTABLE 14	(11) COULD BE UNDER CARPET.	N

**CONDITION CODE**

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)  
 Change in Condition: (4) No (5) Yes (If Yes, explain under comments)  
 Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted  
 Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

**CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS**