

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT DATE 12/28/89

SCHOOL Sierra View Elementary School INSPECTOR Robert Peters

Robert Peters

BLDG. HOMOG. MAT. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
X	Ceiling plaster	1 - 5	All rooms	(#3) (#5) Over
A	PW Cnr	35 - 65	Boiler room	(2) (4)
A	PW Str	5 - 45	Boiler room	(2) (4)
X	Beige VFT 9"	1 - 5	All rooms	(1) Good
B	PW Str	Assumed	Classroom 1 and 3 at radiator	(4)
X	Beige VFT 9"	1 - 5	Rm 5 - A, B, C, D classrooms	(1) Good
C	Air cell	Assumed	Rms 7 & 5 at radiator	(1) Good
X	Beige 9" VFT	1 - 5	Rms 7, 10, 11, 12, 13	(1)
D	Ceiling	1 - 5	Rms 3, 4, 11, 12, 13	(3) (5) Over
D	Hard plaster	1 - 5	Rms 9, 8	(1) Good

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 * OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICT DATE 12/28/89
 SCHOOL Sierra View Elementary School INSPECTOR Robert Peters

BLDG. HOMOG. ASBESTOS MATERIAL LOCATION CONDITION: CODE & COMMENTS

BLDG.	HOMOG.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
D	PW	5 - 10	Rm 11 storage, off MPR	(1) Good (4) No change
D	Mud Cnr	15 - 20	Rm 11 storage	(1) Good
D	Air cell	15 - 20	Rm 8, mechanical room	(1) Good
D	TSI debris	Assumed	Rm 13, behind radiator	(4)
D	Transite pipe	Assumed	Rm 8	(1) Good
E	Mud Jnt	60 - 65	Boiler room	(1) Good
E	Ceiling plaster	1 - 5	RR, custodial closet	(1) Good
X	Grey VFT 9"	10 - 15	Rms 3 & 4	(1) Good
F	Green VFT 9"	1 - 5	Rm 2	(1) Good
F	Ceiling plaster	1 - 5	Rm 3 & 4	(2) (5) Small area. Water stained.

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 & OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]
 ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

