

MEASURE E SCHOOL SITE SURVEY

HOOKER OAK ELEMENTARY

Staff and Parent Advisory Board Recommendations
Kitchen floor needs total resurfacing/rebuilding
Kitchen ovens don't work well
Wing 3 restrooms are dark and dank
Ongoing multiple leaking ceiling areas; roof replacement needed
Electrical circuitry is old thus does not support technology infusion; circuits are blown almost daily
Window frames to garden and nature areas have decaying wood
Hallways and office rooms are freezing
Wing 1 and 2 boy's restroom tile replacement
Only one outside water fountain for students
Concrete foundation and walls have separated; water and ants entry
MPR/Cafeteria drop down tables are aging & nearing obsolete status for parts
No hot water in adult restrooms (heaters installed but see no difference)
Replace carpet in Kindergarten room 18 (it is buckled, grungy and torn)
Linoleum cracking, buckling crack widening at entries of wings 1 and 2
Building inside and outside needs painting
No hot water in health room
Parking lot floods
Blacktop area near basketball area floods
Area by bike racks flood
Need dual pane windows to decrease heat and air conditioning loss in the building
Adult restrooms antiquated (no doors in women's restrooms)
Trees in Nature Center need professional trimming as they are too close to building
Cabinetry in halls is ancient, warped doors, need built-in storage for every classroom

Staff and Parent Advisory Board Recommendations

Access to roof of building by low kitchen overhang needs to be eliminated

Outdoor eating area needs warm weather tenting sun protection

Main office is outdated and cramped

Safety access into building needs modernizing per safety needs of the times

Not all classrooms have LCD projectors mounted

Laptops for all teachers needed

Replace bathrooms floors

A/C needed in kitchen (presently just has an old swamp cooler)

Replace dishwasher

Seal and upgrade basement

New classroom wire and circuit breakers

Replace MPR chairs and racks

Plane the playing fields and level out (renovate)

Replace rotting eaves

Repaint all of building in and out

Repair unusable drinking fountain outside

Replace missing curtain on stage

Strip and re-stain and wax stage flooring

Water bibs needed on portables

Remove tall cypress trees next to the buildings

Remove trees outside wing 3 (drop debris into eaves, blacktop stopping up drains)

Fix outside drainage problems

Remove boiler room asbestos and old boilers

Repair inside and outside custodial mop drains