

CR
ASBESTECH

6801 FAIR OAKS BLVD., SUITE H
CARMICHAEL, CA 95608
(916) 481-8902

Hazard Management Services
P.O. Box 7548
Citrus Heights, CA 95621

Chico U.S.D.
Bidwell Jr.High

ASBESTOS ANALYSIS REPORT

LAB JOB NO: 3512

DATE RECEIVED:

3/11/89

N.V.L.A.P. LAB #1442

E.P.A. LAB #9247

DATE REPORTED:

3/13/89

SAMPLE NO.	COLOR/DESCRIPTION	% TYPE ASBESTOS	% TYPE OTHER
BID-JR-100A	White drywall Music bldg Choral room ceiling	NONE DETECTED	85 Gypsum Binder 15 Cellulose
100B	White drywall Music bldg choral Rm wall practice Rm	1 CHRYSOTILE (in topping)	60 Calcite Binder 30 Gypsum 9 Cellulose
100C	White drywall Music bldg choral Rm wall practice Rm	NONE DETECTED	85 Gypsum 15 Cellulose

THE ANALYSIS USES POLARIZED LIGHT MICROSCOPY AND DISPERSION STAINING FOLLOWING E.P.A. METHOD #600M482020. SAMPLES THAT CONTAIN LESS THAN 1% ASBESTOS ARE NOT CONSIDERED HAZARDOUS BY E.P.A. THIS REPORT MUST NOT BE REPRODUCED EXCEPT IN FULL WITH THE APPROVAL OF ASBESTECH. THIS REPORT RELATES ONLY TO THE ITEMS TESTED. THIS REPORT MUST NOT BE USED BY CLIENT TO CLAIM PRODUCT ENDORSEMENT BY N.V.L.A.P. OR ANY AGENCY OF THE U.S. GOVERNMENT. ASBESTECH AND T.G. CONLON ACCEPT TECHNICAL RESPONSIBILITY FOR THIS TEST REPORT AND DATE OF ISSUE.



SIGNED

J. H. Bala

Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:
Hazard Management Services, Inc.

P.O. Box 6848
Modesto, CA 95355-6848

Client Number: 146
Report Number: 23067
Date Received: 03/29/89
Date Examined: 03/30/89

Lab Number: 8915048
Sample Number: CUSC-BJH 100A
Site:

Analyst: AT

Location:

P.O./Job ID: Chico/Bidwell Jr. High School.

Gross Description: Off-white aggregate.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

Non-Det.%
Non-Det.%
Non-Det.%
%

Non-Det.%

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Fibrous Glass
Polyethylene

Trace %
Trace %
Non-Det.%
%

Trace %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

98-99 %
%
%
%

98-99 %

Supervisor:

David Kahane

David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)

NVLAP

Accredited by the National Bureau
of Standards National Voluntary
Laboratory Accreditation Program for
selected test methods for asbestos

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218

Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:
Hazard Management Services, Inc.

P.O. Box 6848
Modesto, CA 95355-6848

Client Number: 146
Report Number: 23067
Date Received: 03/29/89
Date Examined: 03/30/89

Lab Number: 8915049
Sample Number: CUSC-BJH 100B
Site:

Analyst: AT

Location:

P.O./Job ID: Chico/Bidwell Jr. High School.

Gross Description: Off-white aggregate.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

Non-Det. %
Non-Det. %
Non-Det. %
%

Non-Det. %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Fibrous Glass
Polyethylene

1-5 %
Trace %
Non-Det. %
%

1-5 %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

95-99 %
%
%
%

95-99 %

Supervisor:

David Kahane

David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (ANERA)

NVLAQ

Accredited by the National Bureau of Standards, National Voluntary Laboratory Accreditation Program for selected test methods for asbestos.

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218



Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:
Hazard Management Services, Inc.

Client Number: 146
Report Number: 23067
Date Received: 03/29/89
Date Examined: 03/30/89

P.O. Box 6848
Modesto, CA 95355-6848

Lab Number: 8915050
Sample Number: CUSC-BJH 100C
Site:

Analyst: AT

Location:

P.O./Job ID: Chico/Bidwell Jr. High School.

Gross Description: Off-white aggregate.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

Non-Det. %
Non-Det. %
Non-Det. %
%

Non-Det. %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Fibrous Glass
Polyethylene

1-5 %
Non-Det. %
Non-Det. %
%

1-5 %


TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

95-99 %
%
%
%

95-99 %

Supervisor:



David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)

NVLAQ

Accredited by the National Bureau
of Standards, National Voluntary
Laboratory Accreditation Program for
selected test methods for asbestos

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218



Forensic Analytical Specialties, Inc.

Bulk Material Analysis Report

Client:
Hazard Management Services, Inc.

P.O. Box 6848
Modesto, CA 95355-6848

Client Number: 146
Report Number: 22614
Date Received: 03/15/89
Date Examined: 03/16/89

Lab Number: 8912210
Sample Number: BID-DUCT-A
Site: Not indicated.

Analyst: JM

Location: Duct insulation music bldg.

P.O./Job ID: Not indicated.

Gross Description: Off-White fibrous material.

Comments:

Microscopic Description

TOTAL ASBESTOS PRESENT:

Chrysotile
Amosite
Crocidolite

90-95 %
Non-Det. %
Non-Det. %
%

90-95 %

TOTAL NON-ASBESTOS FIBROUS MATERIAL PRESENT:

Cellulose
Fibrous Glass
Polyethylene

Trace %
Trace %
Non-Det. %
%

Trace %

TOTAL NON-ASBESTOS NON-FIBROUS MATERIAL PRESENT:

Unspecified Particulates

5-10 %
%
%
%

5-10 %

Supervisor: _____

David Kahane
David Kahane

SEE REVERSE FOR EXPLANATION OF TERMS AND REPORTING PRACTICES

Analytical method: 40 CFR 763, Subpart F, Appendix A (AHERA)

Consulting and Laboratory Services in the Forensic and Environmental Health Sciences

3777 Depot Road, Suite 406 - 408, Hayward, CA 94545 415/887-8828 FAX 415/887-4218

N LAD

Accredited by the National Bureau
of Standards, National Voluntary
Laboratory Accreditation Program for
selected test methods for asbestos



Please print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

Manifest Document No.

2. Page 1 of

Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address

Chico Unified School District
2455 Carmichael Dr.
Chico, CA 95928

A. State Manifest Document Number

88663517

B. State Generator's ID

4. Generator's Phone (916) 891-3095

5. Transporter 1 Company Name

A/C Industrial Cleaning Co.

6. US EPA ID Number

C A D D 004 6 9 9 0 0 2

C. State Transporter's ID

900 464

D. Transporter's Phone (916) 343-5488

7. Transporter 2 Company Name

8. US EPA ID Number

E. State Transporter's ID

F. Transporter's Phone

9. Designated Facility Name and Site Address

Anderson Solid Waste
18703 Cambridge Rd.
Anderson, CA 95688

10. US EPA ID Number

C A D D 004 6 9 9 0 0 2

G. State Facility's ID

C A D D 004 6 9 9 0 0 2

H. Facility's Phone

(916) 547-5236

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers
No. Type

13. Total Quantity

14. Unit
Wt/Vol

1. Waste No.

a. RQ Hazardous Waste Solid N.O.S.
(Asbestos) NA 9189

b. 1

c. 1

d. 5

e. Y

State
151

EPA/Other
none

b.

c.

d.

e.

f.

State

EPA/Other

c.

d.

e.

f.

g.

State

EPA/Other

d.

e.

f.

g.

h.

State

EPA/Other

J. Additional Descriptions for Materials Listed Above

Asbestos pipe lagging and vent insulation-double bagged

K. Handling Codes for Wastes Listed Above

a. 03

b.

c.

d.

15. Special Handling Instructions and Additional Information

wear respirators with hepa cartridges and disposable overalls
see attached E.R. Guide book pg. 31

Emergency Contact?
Curtis Hays
916) 343-5488

16.

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

Robert Peters

Signature

Robert Peters

Month Day Year

12/15/91

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

CHAS CURTIS HAYS

Signature

Chas. Curtis Hays

Month Day Year

03/23/91

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Mike Rocha

Signature

Mike Rocha

Month Day Year

03/24/91

19. Discrepancy Indication

RECEIVED

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

N. LARSON

Signature

N. Larson

Month Day Year

12/14/91

88663517

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

Do Not Write Below This Line

Yellow: TSDF SENDS THIS COPY TO GENERATOR WITHIN 30 DAYS

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No. **C A D 9 6 1 4 1 5 2 1 9 6 5 1 7**

2. Page 1 of Information in the shaded areas is not required by Federal law.

3. Generator's Name and Mailing Address
**Chico Unified School District
2455 Carmichael Dr.
Chico, CA 95928**

A. State Manifest Document Number
88663517

4. Generator's Phone (916) **891-3095**

B. State Generator's ID

5. Transporter 1 Company Name
A/C Industrial Cleaning Co.

6. US EPA ID Number
C A D 9 6 0 4 6 9 9 0 0 2

C. State Transporter's ID **900464**

D. Transporter's Phone (916) **343-5488**

7. Transporter 2 Company Name

8. US EPA ID Number

E. State Transporter's ID

F. Transporter's Phone

9. Designated Facility Name and Site Address
**Anderson Solid Waste
18703 Cambridge Rd.
Anderson, CA 95688**

10. US EPA ID Number

G. State Facility's ID
C A D 9 6 1 3 8 8 9 5 2 1

H. Facility's Phone (916) **547-5236**

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers No. Type 13. Total Quantity 14. Unit Wt/Vol I. Waste No.

a. **HQ Hazardous Waste Solid H.O.G.
(Asbestos) NA 9169**

State **151**
EPA/Other **None**

b. State
EPA/Other

c. State
EPA/Other

d. State
EPA/Other

J. Additional Descriptions for Materials Listed Above

Asbestos pipe lagging and vent insulation—double bagged

K. Handling Codes for Wastes Listed Above

a. **03** b.

c. d.

15. Special Handling Instructions and Additional Information

**wear respirators with hepa cartridges and disposable overalls
see attached E.R. Guide book pg. 31**

**Emergency Contact:
Curtis Hays
(916) 343-5488**

18. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.
If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name **Robert Peters** Signature **[Signature]** Month Day Year **11 13 17**

17. Transporter 1 Acknowledgement of Receipt of Materials
Printed/Typed Name **CHAS CURTIS HAYS** Signature **[Signature]** Month Day Year **03 23 19**

18. Transporter 2 Acknowledgement of Receipt of Materials
Printed/Typed Name Signature Month Day Year

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.
Printed/Typed Name Signature Month Day Year

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

88663517

GENERATOR

TRANSPORTER

FACILITY

Please print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

Manifest
Document No.

2. Page 1
of

Information in the shaded areas
is not required by Federal law.

3. Generator's Name and Mailing Address

McWELL Junior High School
2376 North AVE. , Chico CA. 95926

4. Generator's Phone (916) 891-3080

5. Transporter 1 Company Name

A/C Industrial Cleaning Co.

6. US EPA ID Number

C A D 0 3 4 6 9 9 0 8 2

7. Transporter 2 Company Name

8. US EPA ID Number

9. Designated Facility Name and Site Address

ANDERSON SOLID WASTE, INC.
18703 Cambridge Rd.
Anderson, CA. 96007

10. US EPA ID Number

C A D 9 8 1 3 8 8 9 5 2

A. State Manifest Document Number

89526983

B. State Generator's ID

H Y Q Q 3 6 - 0 2 9 8 0 9

C. State Transporter's ID

000760

D. Transporter's Phone (916) 343-5488

E. State Transporter's ID

F. Transporter's Phone

G. State Facility's ID

C A D 9 8 1 3 8 8 9 5 2

H. Facility's Phone

(916) 347-5236

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers

13. Total
Quantity

14.
Unit
Wt/Vol

1.
Waste No.

a. Hazardous Substance n.o.s. NA 9188
(Asbestos) ORM-E

No.

Type

Y

Y

State
151
EPA/Other
none

b.

No.

Type

Y

Y

State
EPA/Other

c.

No.

Type

Y

Y

State
EPA/Other

d.

No.

Type

Y

Y

State
EPA/Other

J. Additional Descriptions for Materials Listed Above

a. Double bagged ACM. Two sheets of transite siding

K. Handling Codes for Wastes Listed Above

a.

03

c.

d.

15. Special Handling Instructions and Additional Information

Wear proclo when handling
Wear Hepa Filters with respirator
See attach E.R. Guidebook pp. 31

EMERGENCY CONTACT

CURT HAYS (916) 343-5488

16.

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

Salvador Antunez

Signature

Salvador Antunez

Month Day Year

10 11 1990

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

James M. Rich

Signature

James M. Rich

Month Day Year

10 11 1990

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

10 11 1990

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in item 19.

Printed/Typed Name

Rex Roberts

Signature

Rex Roberts

Month Day Year

10 11 1990

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

89526983

GENERATOR

TRANSPORTER

FACILITY

Print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

Manifest
 Document No.

2. Page 1
 of

Information in the shaded areas
 is not required by Federal law.

3. Generator's Name and Mailing Address

Bidwell Junior High School
 2376 North AVE. Chico CA. 95926

4. Generator's Phone (916) 891-3080

5. Transporter 1 Company Name

A/C Industrial Cleaning Co.

6. US EPA ID Number

C | A | D | 0 | 3 | 4 | 6 | 9 | 9 | 0 | 8 | 2

7. Transporter 2 Company Name

8. US EPA ID Number

9. Designated Facility Name and Site Address

ANDERSON SOLID WASTE, INC.
 15703 Cambridge Rd.
 Anderson, CA. 96007

10. US EPA ID Number

C | A | D | 9 | 8 | 1 | 3 | 8 | 8 | 9 | 5 | 2

A. State Manifest Document Number

89526983

B. State Generator's ID

H | Y | 0 | 3 | 6 | 4 | 0 | 2 | 9 | 8 | 9

C. State Transporter's ID 000780

D. Transporter's Phone (916) 343-5428

E. State Transporter's ID

F. Transporter's Phone

G. State Facility's ID

H. Facility's Phone

(916) 347-5236

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

a. Hazardous Substance n.o.s. NA 9188

(Asbestos) ORM-E

12. Containers
 No. Type

13. Total
 Quantity

14. Unit
 Wt/Vol

1. Waste No.

State 151

EPA/Other none

State

EPA/Other

State

EPA/Other

State

EPA/Other

J. Additional Descriptions for Materials Listed Above

a. Double bagged ACM. Two sheets of transite siding

K. Handling Codes for Wastes Listed Above

a. 03

c.

b.

d.

15. Special Handling Instructions and Additional Information

Wear proclo when handling
 Wear Hepa Filters with respirator
 See attach E.R. Guidebook pp. 31

EMERGENCY CONTACT

CURT HAYS (916) 343-5486

16.

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

Salvador Antunez

Signature

Salvador Antunez

Month Day Year

10 11 1990

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

James M. Rich

Signature

James M. Rich

Month Day Year

10 11 1990

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

10 11 1990

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

Signature

Month Day Year

10 11 1990

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

Please print or type. (Form designed for use on elite (12-pitch typewriter).)

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

Manifest
Document No.

2. Page 1
of 1

Information in the shaded areas
is not required by Federal law.

3. Generator's Name and Mailing Address

Chico Unified School District
1163 Seventh Street Chico, CA 95928

4. Generator's Phone (966) 891-3000

5. Transporter 1 Company Name

APC Contractors, Inc.

6. US EPA ID Number

CAD120804497

7. Transporter 2 Company Name

APC CONTRACTORS, INC.

8. US EPA ID Number

CAD120804497

9. Designated Facility Name and Site Address

Forward, Inc. Landfill
9999 Austin Rd
Stockton, CA 95203

10. US EPA ID Number

CAD990794133

A. State Manifest Document Number

89820097

B. State Generator's ID

WVW036029809

C. State Transporter's ID

D. Transporter's Phone (209) 441-7971

E. State Transporter's ID

F. Transporter's Phone (209) 441-7971

G. State Facility's ID

CAD990794133

H. Facility's Phone

(209) 982-4298

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

a. RQ, Hazardous Waste Solid, NOS, ORM-E, NA9189
(Asbestos) Cardinal Bagged

12. Containers
No. Type

0101/DR

13. Total
Quantity

000101

14. Unit
Wt/Vol

Y

I. Waste No.

State

151

EPA/Other

State

EPA/Other

State

EPA/Other

State

EPA/Other

J. Additional Descriptions for Materials Listed Above

100% Asbestos Waste Mixture

K. Handling Codes for Wastes Listed Above

a. 03

b.

c.

d.

15. Special Handling Instructions and Additional Information

Project: Bidwell Jr High School, Asbestos Removal (Roof)
DO NOT BREAK BAGS OR CAUSE DUST, AVOID BREATHING DUST. BURY SEPARATELY AND COVER
WITH BACKFILL

16.

GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

ROBERT PETER

Signature

Robert Peter

Month Day Year

10/10/91

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

Ralph Williams

Signature

Ralph Williams

Month Day Year

10/7/91

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Richard W. Burton

Signature

R.W.B.

Month Day Year

10/7/91

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.

Printed/Typed Name

W. Williams

Signature

W. Williams

Month Day Year

10/7/91

Do Not Write Below This Line


89820097

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY



Please print or type. (Form designed for use on elite (12-pitch typewriter).

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. C A D 9 9 0 7 9 4 1 3 3		Manifest Document No. 1		2. Page 1 of 1		Information in the shaded areas is not required by Federal law.							
3. Generator's Name and Mailing Address Chico Unified School District 1163 Seventh Street Chico, CA 95928						A. State Manifest Document Number 89820097									
4. Generator's Phone (916) 891-3000						B. State Generator's ID H Y H N 3 6 0 7 9 8 0 9									
5. Transporter 1 Company Name APC Contractors, Inc.						C. State Transporter's ID D. Transporter's Phone (209) 441-7971									
7. Transporter 2 Company Name						E. State Transporter's ID F. Transporter's Phone									
9. Designated Facility Name and Site Address Forward, Inc. Landfill 9999 Austin Rd Stockton, CA 95203						10. US EPA ID Number C A D 9 9 0 7 9 4 1 3 3 G. State Facility's ID H. Facility's Phone (209) 982-4208									
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)						12. Containers		13. Total Quantity		14. Unit Wt/Vol		15. Waste No.			
a. RQ, Hazardous Waste Solid, NOS, ORM-E, NA9189 (Asbestos)						No. Type		Quantity		Unit Wt/Vol		State EPA/Other			
b.												State EPA/Other			
c.												State EPA/Other			
d.												State EPA/Other			
J. Additional Descriptions for Materials Listed Above 100% Asbestos Waste Mixture						K. Handling Codes for Wastes Listed Above a. 03 b. c. d.									
15. Special Handling Instructions and Additional Information Project: Bidwell Jr High School, Asbestos Removal (Roof) DO NOT BREAK BAGS OR CAUSE DUST. AVOID BREATHING DUST. BURY SEPARATELY AND COVER WITH BACKFILL															
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.															
Printed/Typed Name Robert P. [Signature]						Signature [Signature]						Month Day Year 11/1/91			
17. Transporter 1 Acknowledgement of Receipt of Materials						Printed/Typed Name Robert P. [Signature]						Signature [Signature]		Month Day Year 11/1/91	
18. Transporter 2 Acknowledgement of Receipt of Materials						Printed/Typed Name [Signature]						Signature [Signature]		Month Day Year 11/1/91	
19. Discrepancy Indication Space															
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.															
Printed/Typed Name						Signature						Month Day Year			

89820097
IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY

Do Not Write Below This Line

YELLOW: GENERATOR RETAINS

97337063
IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802: WITHIN CALIFORNIA, CALL 1-800-852-7555

GENERATOR
TRANSPORTER
FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No.		Manifest Document No.		2. Page 1		Information in the shaded areas is not required by Federal law.	
3. Generator's Name and Mailing Address Chico Unified School District 2455 Commercial Drive Chico, CA 95926		4. Generator's Phone (530) 595-3000		5. Transporter 1 Company Name BDC-FALCON SPECIAL WASTE SERVICES		6. US EPA ID Number CA R 0000017657		A. State Manifest Document Number 97337063	
7. Transporter 2 Company Name		8. US EPA ID Number		9. Designated Facility Name and Site Address B & J LANDFILL 5426 HAY ROAD VACAVILLE, CA 95687		10. US EPA ID Number CA D 982042475		B. State Generator's ID	
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers		13. Total Quantity		14. Unit Wt/Vol		I. Waste Number	
a. R.O. ASBESTOS, 9, NA 2212, PGIII (NAERG#171)		213		B A 00017		Y		State 151	
b.								EPA/Other	
c.								State	
d.								EPA/Other	
J. Additional Descriptions for Materials Listed Above		K. Handling Codes for Wastes Listed Above							
FRIABLE ASBESTOS CONTAINING WASTE		a. 03							
15. Special Handling Instructions and Additional Information BDC-FALCON 766 SOUTH AVENUE AZUSA, CA 91702 EPA REGION IX-75 HAWTHORNE ST. BAKMD-939 ELLIS, SAN FRAN, CA ASBESTOS REMOVAL REQUIREMENT 40CFR61 (BAGGED, SEALED & LABELED) WEST COAST		24 HRS. EMERGENCY 1-800-535-5053		B. J. Wells Jr. High School					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.		Printed/Typed Name ROBERT S. PETERSEN		Signature Robert Petersen		Month 07		Day 26	
17. Transporter 1 Acknowledgement of Receipt of Materials		Printed/Typed Name CHARLES M. SIMPSON		Signature Charles M. Simpson		Month 07		Day 26	
18. Transporter 2 Acknowledgement of Receipt of Materials		Printed/Typed Name		Signature		Month		Day	
19. Discrepancy Indication Space									
20. Facility Acknowledgement of Receipt of Materials		Printed/Typed Name R. J. Wells Jr.		Signature R. J. Wells Jr.		Month 07		Day 26	

DO NOT WRITE BELOW THIS LINE.

Yellow: TSDF SENDS THIS COPY TO GENERATOR WITHIN 30 DAYS.
(Generators who submit hazardous waste for transport out-of-state, produce completed copy of this copy and send to DTSC within 30 days.)

c: asbestos bindles

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICTDATE 12/27/89SCHOOL Bidwell Junior High SchoolINSPECTOR Paul B. Graves
GRAVES

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
100	Plaster Ceiling	1 - 5%	All rooms except kitchen	1 - 4
100	9" VFT	Assumed	All rooms except store	1 - 4
100	PW Str	30 - 35%	Chair store. room	1 - 4
100	PW Cnr	Assumed	Kitchen B/R room	1 - 4
100	B/R Lining	60 - 65%	Kitchen B/R room	1 - 4
100	Transite pipe	Assumed	Kitchen B/R room	1 - 4
100	Fan Vent Insul.	Assumed	Fan rooms	1 - 4
200	9" VFT	Assumed	All rooms	1 - 4
200	Plaster	1 - 5%	All rooms	1 - 4
300	Drywall	Assumed	Rm 250, RR, Teach. room	1 - 4
300	9" VFT	Assumed	Rm 250, halls, RR, teach. All classrooms except 105,	1 - 4

106, 107

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 % OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]

ABATED:

(6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICTDATE 12/27/89SCHOOL Bidwell Junior High SchoolINSPECTOR Paul B. Graves

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
300	Ceiling plaster	1 - 5%	Rm 250, halls, RR, teach	1 - 4
300	Ceiling plaster	1 - 5%	All classrooms except 105, 106, 107	1 - 4 (Room 105A - small holes)
300	Transite pipe	Assumed	Closet of Room 405	1 - 4
400	Transite panels	Assumed	Panels in both locker rooms	1 - 4
400	PW Cnr	Assumed	P.E. Boiler room & tunnel	1 - 4
400	Tank wrap	Assumed	P.E. Boiler room	1 - 4
500	Drywall	1%	All rooms	1 - 4
500	9" VFT	Assumed	All rooms	1 - 4
500	Duct Insul.	90 - 95%	Duct work in ceilings	1 - 4 - 10
			and walls	
600	Transite panels	Assumed	Metal Shop	1 - 4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 % OR MORE)
 CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED

SIX-MONTH SURVEILLANCE

DISTRICT CHICO UNIFIED SCHOOL DISTRICTDATE 12/27/89SCHOOL Bidwell Junior High SchoolINSPECTOR Paul B. Graves

BLDG.	HOMOG. MAT.	ASBESTOS MATERIAL	LOCATION	CONDITION: CODE & COMMENTS
600	9" VFT	Assumed	Room 8 and office	1 - 4
600	Asbestos curtain	Assumed	Metal shop	5 - 7 (Removed)
600	Mud Jnts	1 - 5%	(Rm 9) Rm 208 near sink	1 - 4
600	12" VFT	Assumed	Room 9	1 - 4
700	9" VFT	Assumed	All classrooms	1 - 4
700	Mud Jnts	1 - 5%	Rooms 408 & 409	1 - 4
800	9" VFT	Assumed	Library	1 - 4
900	PW Str	15 - 20%	Gym, B/R, Storeroom	1 - 4
900	PW Cnr	5 - 10%	Gym, B/R, Storeroom	1 - 4

CONDITION CODES

GENERAL CONDITION: (1) GOOD (2) DAMAGED (3) SIGNIFICANTLY DAMAGED (DAMAGED 2 + OR MORE)

CHANGE IN CONDITION: (4) NO (5) YES [IF YES, EXPLAIN UNDER COMMENTS]

ABATED: (6) REPAIRED (7) REMOVED (8) ENCAPSULATED (9) ENCLOSED (10) ISOLATED & RESTRICTED