

**ENTEK CONSULTING GROUP, INC.  
ASSESSMENT OF TSI and/or FRIABLE MATERIAL**

District: Chico Unified School District

Date: July 8, 2010

School: District Office

Inspector: Jack DeLay

Building & Location(s): Basement Crawl Space

Sample#: HMS-DO-07A

% Asbestos- 80-85%

Homogeneous Mat. #8

Material description: Pipe Wrap Straight

Total amount of material this location: 350 L

Amount of friable material this location: 350 L

Damage	Local		Distributed	X	Damaged	98%
Type of Damage	Air Erosion	X	Water	X	Flaking	X
	Deterioration	X	Physical	X	Delamination	

Probable cause(s) of damage: Unknown

POTENTIAL FOR DISTURBANCE			RESPONSE ACTIONS		PREVENTIVE MEASURES	
	H	M	L	Isolate/Restrict		Fix leaks
Accessibility	X			Repair/Cleanup	X	Prevent water contact
Vibration			X	Enclose		Do not drill, cut, sand, or grind
Air Erosion		X		Remove	X	Do not affix signs
Water		X		Encapsulate		Avoid contact
Occupancy			X	O & M		

**Assessment of Material Condition**

Significantly Damaged  
(Poor)

Damaged  
(Fair)

Not damaged  
(Good)




Potential  
Damage:

High

High

Mod

Low

High

Mod

Low

Hazard  
Ranking:

1

2

3

4

5

6

7

--	--	--	--	--	--	--	--	--

Comments & Observations:

Was instructed by Leroy Christopher not go into the basement crawl space. Possibly removed and could not locate.