

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 06/09/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
						BUILDING A - BURNED DOWN 10-06-00, REBUILT IN 2001. DISTRICT MUST CERTIFY.	

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	1	NONE DETECTED	4,500 S	LIBRARY AND CLASSROOMS 6, 9, AND 10	(13) REPRESENTED BY SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	2,500 S	ENTIRE WING	(1) (4)	N
M	DRYWALL	80	ASSUMED	1,500 S	CLASSROOMS 6, 9, AND 10	(1) (4)	N
M	TRANSITE PANEL	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 06/09/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary School

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP S	1	NONE DETECTED	7,000 S	OFFICE AND CLASSROOMS 7, 8, 11, 12, AND 13	(13) SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	600 S	OFFICE	(1) (4) CARPET OVER TILE IN PRINCIPAL OFFICE AND PART OF MAIN OFFICE.	N
S	PLASTER	86	ASSUMED	250 S	MEN S & WOMEN S RESTROOM CEILINGS	(1)	N
M	TRANSITE PANELS	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

Building: Portables 4 and 19-21 (FKA 19-22)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	88	ASSUMED	3,200 S	PORTABLES 4 AND 19-21	(1) (4) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N
M	12" VFT WHITE/BLUE	89	ASSUMED	3,200 S	PORTABLES 4 AND 19-21	(1) (4) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.). NOTE: DISTRICT MUST CERTIFY.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)

Change in Condition: (4) No (5) Yes (If Yes, explain under comments)

Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted

Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 06/09/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary School

Building: Portables 22-24 (FKA 23-26)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	87	ASSUMED	2,800 S	PORTABLES 22-24	(1) (4) THESE PORTABLES HAVE A 1/98 MFG. DATE. DISTRICT CERTIFICATION REQUIRED.	N
M	DRYWALL	111	ASSUMED	3,000 S	PORTABLES 22-24	(11) COULD BE BEHIND TAGBOARD.	N

Building: Portables 16-18

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT TAN	109	ASSUMED	2,700 S	PORTABLES 16-18	(1) (4)	N
M	2' X 4' FCP S	110	ASSUMED	2,700 S	PORTABLES 16-18	(1) (4)	N
M	DRYWALL	111	ASSUMED	2,700 S	PORTABLES 16-18	(1) (4) (11) DRYWALL BEHIND TAGBOARD.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 06/09/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary

Building: Portables 14, 14A, and 15 (FKA Speech and Portable 14)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	60	NON SUSPECT	2,200 S	PORTABLES 14, 14A, AND 15	(13) FIBERGLASS - NON SUSPECT ASBESTOS CONTAINING BUILDING MATERIAL.	N
M	12" VFT WHITE	70	ASSUMED	2,300 S	PORTABLES 14, 14A, AND 15	(11) COULD BE UNDER CARPET.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary School

Building: A

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
						BUILDING A - BURNED DOWN 10-06-00, REBUILT IN 2001. DISTRICT MUST CERTIFY.	

Building: B

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	1	NONE DETECTED	4,500 S	LIBRARY AND CLASSROOMS 6, 9, AND 10	(13) REPRESENTED BY SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	2,500 S	ENTIRE WING	(1) (4)	N
M	DRYWALL	80	ASSUMED	1,500 S	CLASSROOMS 6, 9, AND 10	(1) (4)	N
M	TRANSITE PANEL	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary School

Building: C

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2 X 4 FCP S	1	NONE DETECTED	7,000 S	OFFICE AND CLASSROOMS 7, 8, 11, 12, AND 13	(13) SAMPLE HMS-SHA-01 COLLECTED IN 1988.	N/A
M	12" VFT BEIGE	2	TRACE	600 S	OFFICE	(1) (4) CARPET OVER TILE IN PRINCIPAL OFFICE AND PART OF MAIN OFFICE.	N
S	PLASTER	86	ASSUMED	250 S	MEN S & WOMEN S RESTROOM CEILINGS	(1) (4)	N
M	TRANSITE PANELS	99	ASSUMED	5,000 S	OUTSIDE BUILDING	(1) (4)	N

Building: Portables 4 and 19-21 (FKA 19-22)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	88	ASSUMED	3,200 S	PORTABLES 4 AND 19-21	(1) (4) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.).	N
M	12" VFT WHITE/BLUE	89	ASSUMED	3,200 S	PORTABLES 4 AND 19-21	(1) (4) THESE PORTABLES HAVE A MFG. DATE OF 4/97. DISTRICT CERTIFICATE REQUIRED (DMSI MFG.). NOTE: DISTRICT MUST CERTIFY.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary School

Building: Portables 22-24 (FKA 23-26)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	87	ASSUMED	2,800 S	PORTABLES 22-24	(1) (4) THESE PORTABLES HAVE A 1/98 MFG. DATE. DISTRICT CERTIFICATION REQUIRED.	N
M	DRYWALL	111	ASSUMED	3,000 S	PORTABLES 22-24	(11) COULD BE BEHIND TAGBOARD.	N

Building: Portables 16-18

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	12" VFT TAN	109	ASSUMED	2,700 S	PORTABLES 16-18	(1) (4)	N
M	2' X 4' FCP S	110	ASSUMED	2,700 S	PORTABLES 16-18	(1) (4)	N
M	DRYWALL	111	ASSUMED	2,700 S	PORTABLES 16-18	(1) (4) (11) DRYWALL BEHIND TAGBOARD.	N

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

**SIX MONTH SURVEILLANCE
HOMOGENEOUS ACBM RECORDS**

Date of Inspection: 12/27/2005

District: Chico Unified School District

Inspector: Leroy Christophersen

School: Shasta Elementary

Building: Portables 14, 14A, and 15 (FKA Speech and Portable 14)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	2' X 4' FCP S	60	NON SUSPECT	2,200 S	PORTABLES 14, 14A, AND 15	(13) FIBERGLASS - NON SUSPECT ASBESTOS CONTAINING BUILDING MATERIAL.	N
M	12" VFT WHITE	70	ASSUMED	2,300 S	PORTABLES 14, 14A, AND 15	(11) COULD BE UNDER CARPET.	N

Building: Portables 25 & 26 (From Former Fair View/Cal Campus)

Material Class	Material	Homo. Mat. #	% Asb.	Ft ² /L.F.	Location	Condition: Code & Comments	Friable Yes/No
M	DRYWALL		ASSUMED		(PORTABLES 12 C5 from former FVAIR VIEW) CLASSROOMS 25 & 26	(12) MANUFACTURES DATE 1989. DISTRICT CERTIFICATION REQUIRED (1)	
M	2' X 4' FCP'S		NON DETECT		CLASSROOMS 25 & 26	(13) CUSD SAMPLE #SH01 & SH03 7/29/2005	
M	12" VFT GREY		NON DETECT		CLASSROOMS 25 & 26	(13) CUSD SAMPLE #SH02 7/29/2005	

CONDITION CODE

General Condition: (1) Good (2) Damaged (3) Significantly Damaged (25% or more)
Change in Condition: (4) No (5) Yes (If Yes, explain under comments)
Abated: (6) Repaired (7) Removed (8) Encapsulated (9) Enclosed (10) Isolated & Restricted
Miscellaneous: (11) Inaccessible, no inspection data (12) Other (Explain under comments) (13) Non-Asbestos/Not Inspected

CONSULT ORIGINAL AND SUPPLEMENTARY INSPECTION REPORTS FOR MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

From The Desk Of

Leroy A. Christophersen

Maintenance & Operations ♦ 2455 Carmichael Drive ♦ Chico, CA 95928 ♦ (530) 891-3195 ♦ lchristo@chicousd.org

Date: July 28, 2005

To: Asbestos Binders for:
Chico Junior High School
Former Fair View High School (now Chico Country Day School)
John Mc Manus Elementary School
Shasta Elementary School

From: Leroy A. Christophersen, Safety & Loss Control Coordinator

Re: Relocated Buildings

This memo is to advise that the following changes have been made at the sites listed above.

- Room P-1 has been moved from Chico Junior High School and relocated to John McManus Elementary School.
- Room 15 & 16 have been moved from the former Fair View High School (now CCDS) and relocated to John McManus Elementary School.
- Room 12 has been moved from the Former Fair View High School (now CCDS) and relocated to Shasta Elementary School.
- Room C5 has been moved from the Former Fair View High School (now CCDS) and relocated to Shasta Elementary School.

LC/dlg



Maintenance and Operations
2455 Carmichael Drive
Chico, CA 95928
Phone: (530) 891-3195
Fax: (530) 891-3190

Chico Unified School District

Fed Ex Airbill #8358 1795 0893

July 20, 2005

Forensic Analytical Specialties, Inc.
3777 Depot Road, Suite 409
Hayward, CA 94545

Re: Mc Manus & Shasta Elementary Schools

To Whom It May Concern:

Please test the enclosed samples from the portable classrooms recently relocated from the former Fair View High School for asbestos. We would like a 48-hour turnaround on the samples. Please fax the results to us as soon as they are available. Our fax number is (530) 891-3190.



Site Sampled:

Location:
Item Sampled:
Date Sampled:
Number of Samples:

McManus Elementary School

Portable #15 from Fair View
FCT
July 29, 2005
One (1) – #Mc 001

Location:
Item Sampled:
Date Sampled:
Number of Samples:

Portable #15 from Fair View
VFT
July 29, 2005
One (1) – #Mc 002

Site Sampled:

Location:
Item Sampled:
Date Sampled:
Number of Samples:

Shasta Elementary School

Portable #12 from Fair View
FCT
July 29, 2005
One (1) – #Sh01

Location:
Item Sampled:
Date Sampled:
Number of Samples:

Portable #12 from Fair View
VFT
July 29, 2005
One (1) – #Sh02

Location:
Item Sampled:
Date Sampled:
Number of Samples:

Portable #C5 from Fair View
FCT
July 29, 2005
One (1) – #Sh03

Thank you for your prompt response to this request.

Sincerely,

Leroy Christophersen
Safety & Loss Coordinator

LC:dlg
Enclosures